

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	3	2	3	2	3			
2	NLG	144	988		10		10		10			
3	MDK	107	933	2	4	2	4	2	4			
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	19	4	19	4	19	0	0	
	Grand Total	1082	6468	4	25	4	25	4	25	0	0	

TSSPDCL - LMRC / Corporate office

Date: 12.06.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Rajapur	33KV	Jadcherla	08.40	10.25	01.45	E/L	Jumper Touch to the Pole Near Surya Jyothi Industry Rajapur	Balanagar	No
2		Balanagar	G R Cable	33KV	Jadcherla	15.03	15.45	00.42	E/L	AB Switch open at Gundlapotlapally Village due to Jumper touch to the Pole	Balanagar	No
1	MDK	Bollaram	Bollaram-II	33KV	Patancheru	12.00	13.30	01.30		BD due to Jumper cut	Bollaram	No
2		Zaheerabad	Jharasangam	33KV	Zaheerabad	13.30	16.40	03.10		BD due to Pin Binding failed	Zaheerabad	No

TSSPDCL - LMRC / Corporate office

Date: 12.06.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Rajapur	Chennavelly	11KV	Jadcherla	07.10	11.30	04.20		Tree Fallon the line near Rapally	-
2		Rajapur	Chennavelly	11KV	Jadcherla	13.50	15.00	01.10		Tree Fallon the line near Rapally	-
3		Janampet	Polkampally	11KV	Jadcherla	08.50	12.10	03.20		11KV Wire cut near Polkampally	-
1	NLG	Mattapally	Sulthanpuram	11KV	Huzurnagar	11.10	14.10	03.00	EL	11Kv jumper cut	-
2		Timmareddy gudem	Timmareddy gudem	11KV	Huzurnagar	11.30	14.00	02.30	EL	Vehicle hit the 11Kv pole	-
3		Chanupally	Tripuravaram	11KV	Huzurnagar	05.35	08.35	03.00	EL	11Kv jumper cut	-
4		Jalalpuram	Velishala X road	11KV	Suryapet	14.00	16.30	02.30	E/L	11Kv Insulator flashover	-
5		Thimmapuram (Ramadugu)	Ramadugu	11KV	Miryalguda	10.28	11.20	00.52	E/L	11Kv Insulator flashover	-
6		Akaram	Vallala	11KV	Nalgonda	03.50	06.02	02.12	E/L	11 KV Jumper Cut and Fallen on the X arm	-
7		Pamanagundla	Yerrasanigudem	11KV	Nalgonda	03.40	06.30	02.50	E/L	11 KV Jumper Cut	-
8		Peddathanda	Pallepahd	11KV	Bhongir	06.30	08.00	01.30	E/L	11kv Insulator Failed near Pallepahd Village	-
9		Gundala	Gangapur	11KV	Bhongir	10.00	10.45	00.45	E/L	SS-9 DTR 11kv Insulator Failed	-
10		Narayanpur	Maillacharu	11KV	Choutuppal	05.00	10.15	05.15	E/L	SS-33 100KV DTR Failed	-
1	MDK	Gaddapotharam -I	United	11KV	Patancheru	18.05	20.30	02.25		B/D due to Tree branches fallen on the line	-
2		Pati	Shalimar	11KV	Patancheru	13.00	15.15	02.15		B/D due to Insulator failed	-
3		Pati	My Home	11KV	Patancheru	16.40	18.40	02.00		B/D due to Jumper cut	-
4		SRD-Town -II	No.III	11KV	Sangareddy	15.05	18.10	03.05		B/D due to Conductor snapped	-
5	SDPT	Akkannapet	Akkannapet Rural	11KV	Husnabad	18.40	21.25	02.45		BD due to jumper cut	-
6		Komuravelly	Posanpally	11KV	Husnabad	17.48	19.40	01.52		BD, Conductor snapped	-
1	RR S	Nanakramguda	N'Widia	11KV	Gachibowli	12.36	17.00	04.24		11KV UG Cable Failed at Andhra Bank. Nanakramguda	-
1	RR N	HMT	Ganesh Nagar	11KV	Medchal	15.20	16.00	00.40		11KV Line AB Switch Opened at Dilkush Nagar	-
1	RR E	Cherlapally-IV	Sai Nagar	11KV	Sainikpuri	11.10	11.40	00.30		Copper Patti cut on 11Kc Pole Toched at Sai Nagar Kamman (L Insp Kishor Raju)	-
2		Vasanthapuri	Venkateshwara Nagar	11KV	Sainikpuri	15.53	17.27	01.34		UG Out Going Cable fail at near SS (L Insp Narsinga Rao)	-
1	HYD N	Nehru Nagar	Contonment	11KV	Bowenpally	11.17	13.55	02.38	OL-R&Bph	O/G Cable fault at Court Office	Partial fdr charged & remaining loads added on 11KV West Marredpally fdr
1	HYD S	Hyderguda	Janapriya ABC	11KV	Charminar	20.15	21.45	01.30	EL,OL	Cable fault at Shamshan Gate	Arranged B/F on 11KV W.S.Colony fdr