

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		14		14		14			
3	MDK	107	933									
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	18	0	18	0	18	0	0	
	Grand Total	1082	6468	0	19	0	19	0	19	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.06.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kodgal	Kodgal	11KV	Jadcherla	11.45	14.45	03.00		Pin binding fail near Kodgal	-
1	NLG	Narkatpally	Mandra	11KV	Nalgonda	12.30	15.40	03.10	E/L	11 KV Jumper Cut	-
2		P.D.Pally	Kanchanapally	11KV	Nalgonda	14.30	17.12	02.42	E/L	11 KV line jumper cut	-
3		Peddavoora	Nayanivanikunta	11KV	Miryalaguda	08.56	10.40	01.44	E/L	11 KV Jumper Cut	-
4		Bopparam	Kothagudem	11KV	Suryapet	11.55	14.50	02.55	E/L	Disc Flashover	-
5		Gondiryala	Chimiryala	11KV	Huzurnagar	01.50	04.50	03.00	EL	11 KV LINE SNAPPED	-
6		Kalmalcheruvu	Kalmalcheruvu	11KV	Huzurnagar	05.05	06.10	01.05	EL	11 KV LINE SNAPPED	-
7		Kandibanda	N B Gudem	11KV	Huzurnagar	14.00	16.30	02.30	EL	11 KV DISK FAILED	-
8		Mukundapuram	Kalluru	11KV	Huzurnagar	07.00	09.40	02.40	EL	11 KV JUMPER CUT	-
9		Raghunadapalem	Gundlapally	11KV	Huzurnagar	06.00	09.30	03.30	EL	11 KV LINE SNAPPED	-
10		Chanupaaly	Chanupally	11KV	Huzurnagar	06.30	09.25	02.55	EL	11 KV DISK FAILED	-
11		MT.Pally	Vasalamarry	11KV	Bhongir	11.45	15.00	03.15	EL	11 KV Jumper Cut Near Vasalamarry Village	-
12		Ambala	Modubavigudem	11KV	Bhongir	10.30	15.15	04.45	OL	11 KV Line Snapped Near Kapraipally Village	-
13		Gundala	Nunegudem	11KV	Bhongir	11.50	18.00	06.10	EL	11 kv Disc Failed at SS-5 Near Nunegudem Village	-
14		Koyalagudem	Dothigudem Indl	11KV	Choutuppal	05.27	08.45	03.18	EL	11 kv Jumper Cut Near Dothigudem Village	-
1	SDP	Bejjanki	Kallepally	11KV	Husnabad	00.00	01.30	01.30		Line fault same rectified	-
2		Thotapally	Mallampally	11KV	Husnabad	11.15	11.35	00.20		Insulator failure same rectified	-
3		Thotapally	Thotapally Rural	11KV	Husnabad	14.30	17.30	03.00		Line fault same rectified	-
1	HYD C	Chilalguda	Bholakpur	11KV	I	12.45	14.10	01.25	EL,OL-Rph	O/G Jumper cut at SS	-