

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		13		13		13			
3	MDK	107	933									
4	SDPT			1	7	1	7	1	7			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	21	1	21	1	21	0	0	
	Grand Total	1082	6468	1	29	1	29	1	29	0	0	

TSSPDCL - LMRC / Corporate office

Date: 15.06.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	SDPT	Mustyala	Komuravelly	33KV	Husnabad	06.30	08.00	01.30		33kv line jumper belt on 11kv line	Komuravelly	-

TSSPDCL - LMRC / Corporate office

Date: 15.06.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nawabpet	Kondapur	11KV	Jadcherla	14.20	16.20	02.00		11KV Wire Cut Near Adilapur Thanda	-
1	NLG	Shaligouraram	Ambaripeta	11KV	Nalgonda	09.30	16.30	07.00	E/L	Tree branches fallen on line at SS-5	-
2		Arlagaddagudem	N.R.Gudem	11KV	Nalgonda	14.20	17.10	02.50	E/L	HT/LT melting	-
3		Marrigudam	Konduru	11KV	Devarakonda	02.00	12.00	10.00	E/L	Jumper Cutt	
4		Aipoor	Express Feeder	11KV	Suryapet	08.05	10.18	02.13	E/L	Conductor snapped	
5		Mattampally	Errajelu	11KV	Huzurnagar	04.15	09.30	04.45	E/L	11 KV LINE SNAPPED	
6		Dirincherla	Town-1	11KV	Huzurnagar	12.40	13.50	01.10	E/L	11 KV JUMPER CUT	
7		Palakeedu	Palakeedu	11KV	Huzurnagar	12.00	15.20	03.20	E/L	11 KV LINE SNAPPED	
8		Huzurnagar	Lakkaram	11KV	Huzurnagar	12.00	15.30	03.30	E/L	11 KV LINE SNAPPED	
9		Raghunadapalem	Gundlapally	11KV	Huzurnagar	07.30	10.45	03.15	E/L	11 KV LINE SNAPPED	-
10		IDA	Housing board	11KV	Bhongir	06.05	06.35	00.30	E/L	11 kv Line Snapped	-
11		Mothkur	Anajipur	11KV	Bhongir	08.05	09.20	01.15	E/L	11kv Line Snapped	-
12		Panthangi	Panthangi Indl	11KV	Choutuppal	09.40	11.40	02.00	E/L	11kv Insulator Failed	-
13		Jublakpally	Kanmukula	11KV	Choutuppal	04.00	05.50	01.50	E/L	Tree Fallen at Line	-
1	SDPT	Husnabad	Pandilla & Malapally	11KV	Husnabad	09.15	13.00	03.45		11kv line jumper cutting	-
2		Katkur	Ramavaram & Mallaram	11KV	Husnabad	07.30	13.05	05.35		top phase pin binding	-
3		Ramchandrapur	Vinjalpally	11KV	Husnabad	02.40	07.05	04.25		Jumper cutting	-
4		Ramchandrapur	Vinjalpally	11KV	Husnabad	09.05	11.20	02.15		Jumper cutting	-
5		Koheda	Kurella	11KV	Husnabad	12.32	16.55	04.23		11kv line cutting	-
6		Akunoor	Dommata	11KV	Husnabad	09.05	19.10	10.05		copper patty cutting	-
7		Chityal	Dommata	11KV	Husnabad	13.55	15.40	01.45		Jumper cutting	-
1	RR S	Gachibowli	Sudharshan Nagar	11KV	Gachibowli	09.20	11.30	02.10	BD	11kv pin-insulator failed at Dohen's backside	-
2		Gachibowli	Sai Baba	11KV	Kondapur	01.55	03.00	01.05	BD	Line petrolling, No Visible fault found	-
1	RR N	Jeedimetla-IV	A A I matha	11KV	Jeedimetla	12.11	13.34	01.23	BD	11kv Pin Insulator failure At Little high school	-
2		Kolthur	Kolthur	11KV	Medchal	17.50	20.00	02.10	BD	11KV Pin Insulator failed at Kolthur Village	-
1	RR E	Aushapur	Bokkenguda	11KV	Keesara	13.00	14.10	01.10		11KV Pole damaged at Ghanapur Village	-
2		P&T Colony	NIN	11KV	Keesara	17.40	18.40	01.00		Line patrolling but no visible fault & AB Switch opened at P&T Colony	-
1		Fever Hospital	Tourist Hotel	11kv	Azamabad	11.14	12.51	01.37	EL	Cable fault near SS	Arranged B/F on 11KV M.A Nagar feeder

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
2	HYD C	Bathakamma Kunta	Saibaba Temple	11kv	Azamabad	19.15	20.56	01.41	All Indication	No Visible Fault	(20:30 Hrs) partial loads aranged B/F on 11KV C.E Colony feeder