

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		15		15		15			
6	RR(N)	54	550	1	7	1	7	1	7			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044	1	24	1	24	1	24			
	Total	606	3055	2	49	2	49	2	49	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	9	1	9	1	9	1			
2	NLG	144	988	3	19	3	19	3	19			
3	MDK	107	933	2	2		2		2			2 Nos 33KV Still
4	SDPT			1	14	1	14	1	14			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	15	36	13	36	13	36	0	0	
	Grand Total	1082	6468	17	85	15	85	15	85	0	0	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Ghanpoor	33KV	Mahabubnagar	16.20	16.40	00.20	EL&OL	No Visible fault	Ghanpoor	Alternate Supply Arranged from 220KV Palkonda SS at 16:40Hrs
2		Maddur	Maddur	33KV	Narayanapet	16.40	18.15	01.35	EL	Pin Binding Replaced at Maddur	Maddur	-
3		Maddur	Vepoor	33KV	Narayanapet	16.40	19.20	02.40	EL	2No's Pin Insulators failed and Replaced at Pedirepadu Road	Vepoor	-
4		Maddur	Koilkonda Water Grid	33KV	Narayanapet	18.50	20.00	01.10	EL	No Visible fault	Koilkonda Water Grid	Alternate Supply Arranged from 33KV Parepally SS at 20:00Hrs
5		Thirumalaipally	Veltoor	33KV	Wanaparthi	18.35	18.56	00.21	EL	No Visible fault	Veltoor	Alternate Supply Arranged from 33KV Kothakota feeder at 18:56Hrs
6		Gadwal	Nandinne	33KV	Gadwal	22.35	23.55	01.20	EL	Insulator failed	Nandinne	-
7		Kodangal	Kothur	33KV	Vikarabad	16.58	18.40	01.42	EL	Disc Failed at Lingampally	Kothur	-
8		Kothur	SANGEM	33KV	Shadnagar	15.20	17.25	02.05	OL	Tree fallen on the line and removed	SANGEM	-
9		Shadnagar	Rayalseema	33KV	Shadnagar	15.05	18.30	03.25	EL	B Phase out going side jumper cut at 220KV SDNR SS	Rayalseema	-
1	NLG	Suryapet	Chandupatla	33KV	Huzurnagar	02.30	09.00	09.00	EL	Due to 33kv Insulator Failure	Chandupatla	-
2		Dirsincherla	K.V.Gudem	33KV	Huzurnagar	19.55	10.25	10.25	EL	Due to 33kv line Snapped	K.V.Gudem	-
3		Ramapuram	Mellacheruvu	33KV	Huzurnagar	00.00	08.00	08.00	EL	Due to tree branch fall on 33kv line	Mellacheruvu	-
1	MDK	Narayankhed	Waser	33KV	Jogipet	23.00	Still				Waser	-
2		Sadashivpet	Jogipet	33KV	Sangareddy	23.40	Still				Jogipet	-
1	SDP	Palamakula	Gonepaaly	33KV	Siddipet	00.00	08.25	08.25		BD Due to tree fallen	Gonepaaly	-
1	RR N	220KVA Shapur Nagar	33KV Agarwal	33KV	Medchal	19.57	19.10	23.13		33KV UG Cable failed	33KV Agarwal	-
1	HYD N	132KV J' Hills	MLA Colony	33KV	Kalyan Ngr	06.25	06.29	00.04	EL,OL-Rph	Cable End Kit failed at K.B.R Park	MLA Colony	Loads trasferred onto 132KV J' Hills SS via 33KV Asif Ngr Ckt-1

TSSPDCL - LMRC / Corporate office

Date: 21.06.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Konded	Konded	11KV	Jadcherla	10.05	13.50	03.45		Psase to Phase near Konded	-
1	NLG	Narsingbatla	Kuthurugudem	11KV	Nalgonda	11.03	12.05	01.02	EL	LT Line /HT Melting	-
2		G.Yedavelly	Shadbullapuram	11KV	Nalgonda	04.00	10.50	06.50	EL	LT Line /HT Melting	-
3		Wangamarthy	Wangamarthy	11KV	Nalgonda	07.00	09.00	02.00	EL	11 KV Line Jumper Cut	-
4		Jammigadda	Kesaram	11KV	Suryapet	07.00	09.15	02.15	EL	Insulator failed	-
5		Kodur	Loyapally	11KV	Suryapet	11.00	13.00	02.00	EL	HT/LT Line melt	-
6		Akupamula	Singaram	11KV	Huzurnagar	05.30	06.30	01.00	EL	Due to 11Kv Jumper cutted	-
7		Kistapuram	Thammaram	11KV	Huzurnagar	05.20	07.30	02.10	EL	Due to 11Kv jumper cutted	-
8		Huzurnagar	Lakkavaram	11KV	Huzurnagar	02.35	06.00	03.25	EL	Due to 11Kv insulator failure	-
9		Repala	Repala	11KV	Huzurnagar	04.00	07.35	03.35	EL	Due to bird fall on 11kv line	-
10		Nadigudem	Ramapuram	11KV	Huzurnagar	04.50	08.10	03.20	EL	Due to 11Kv jumper cutted	-
11		Mamillagudem	Mothey agl	11KV	Huzurnagar	02.30	06.15	03.45	EL	Due to 11Kv jumper cutted	-
12		N.B.Gudem	Rizwin	11KV	Huzurnagar	14.05	15.25	01.20	EL	Due to bird fall on 11kv line	-
13		Sharajipeta	Sharajipeta	11KV	Bhongir	12.00	14.50	02.50	EL	11 KV Line Snapped	-
14		Paladugu	Dattappagudem	11KV	Bhongir	05.30	09.10	03.40	EL	2 no's 11 kv Disc Failed	-
15		Addagudur	Addagudur	11KV	Bhongir	06.00	09.25	03.25	EL	11 kv Insulator Failed	-
16		Addagudur	Addagudur Indl	11KV	Bhongir	06.30	07.45	01.15	EL	11 kv Insulator Failed	-
17		Gundala	Nunegudem	11KV	Bhongir	07.10	11.30	04.20	EL	11 Insulator Failed	-
18		Ramannapeta	Dubbaka	11KV	Choutuppal	09.00	13.25	04.25	EL	11 KV Insulator Failed	-
19		Golnepally	Golnepally	11KV	Choutuppal	09.30	10.10	00.40	EL	11 kv Jumper cut	-
1	MDK	Munpally	Buddera	11KV	Sangareddy	13.16	18.23	05.07		Conductor snapped	-
2		Sangareddy Town-II	No-I	11KV	Sangareddy	21.50	23.10	01.20		Tree branches fallen on line	-
1		Pandilla	Potlapally	11KV	Siddipet	00.00	01.30	01.30		Breakdown due to Rain	-
2		Gandipally	Ramavaram	11KV	Siddipet	00.00	09.30	09.30		Insulator Fail	-
3		Gandipally	Ramavaram Exp	11KV	Siddipet	00.00	12.00	12.00		Insulator Fail	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
4	SDP	Gouravelly	Gudatipally	11KV	Siddipet	00.00	06.45	06.45		Breakdown due to Rain	-	
5		Bejjanki	Kallepally	11KV	Siddipet	00.00	07.20	07.20		Tree cutting	-	
6		Bejjanki	Muthannapet	11KV	Siddipet	00.00	11.00	11.00		Jumper cutting	-	
7		Guggilla	Thimmaipally	11KV	Siddipet	00.00	16.40	16.40		Insulator Fail	-	
8		Thotapally	Dacharam (Exp), Dacharam (R) , Thotapally ®	11KV	Siddipet	00.00	08.15	08.15		Insulator Fail	-	
9		Thotapally	Thotapally (Exp)	11KV	Siddipet	00.00	08.30	08.30		Disk Fail	-	
10		Mustyal	Mustyal	11KV	Siddipet	00.30	06.00	05.30		Line cutting	-	
11		Komuravelly	Komuravell 24 Hrs	11KV	Siddipet	07.50	14.05	06.15		11KV Insulator Problem	-	
12		Komuravelly	Kadavergu	11KV	Siddipet	08.50	11.35	02.45		11KV Insulator Problem	-	
13		Komuravelly	Inapur + Posanpally + Inapur 24 Hrs	11KV	Siddipet	07.50	14.05	06.15		11KV Insulator Problem	-	
14		Gagillapur	Narsaipally	11KV	Siddipet	16.30	18.12	01.42		Jumper cutting	-	
1		RR S	Shamshabad	Madhuranagar	11KV	RJNR	07.18	09.20	02.02	BD	11kv Cable Fault at Rallaguda	-
2			MD Pally	Bandlaguda	11KV	RJNR	16.25	17.30	01.05	BD	Plastic cement bags Fallen on 11kv Line at ice factory	-
3	NPA		Shivarampally	11KV	RJNR	16.35	17.42	01.07	BD	11kv Insulator Failed at Pillar No 298 Due To Rain	-	
4	IIIT		J.V.Colony	11KV	Gachibowli	16.48	18.20	01.32	BD	Due to heavy wind and rain	-	
5	IIIT		Kindriya Vihar	11KV	Gachibowli	16.55	18.06	01.11	BD	Due to heavy wind and rain	-	
6	Nanakramguda		TNGO's Colony	11KV	Gachibowli	17.26	18.44	01.18	BD	1)Due to heavy wind and rain 2) 100kva T/F HG fuse insulator failed near park, Komarambeam X-road	-	
7	ESCI		Nanakramguda	11KV	Gachibowli	18.32	19.38	01.06	BD	11kv Line AB-Switch Jumper cut at Ramana fire works	-	
8	Papireddy colony		Papireddy colony	11KV	Gachibowli	18.50	19.50	01.00	BD	11kv Disk failed at Placeda Company, Papireddy colony	-	
9	Chanda Nagar		Engineers Enclave	11KV	Gachibowli	18.00	19.10	01.10	BD	Due to heavy wind and rain, Tree fallen on the 11kv line at KBR Apartment, Engineers Enclave	-	
10	Chanda Nagar		Market	11KV	Gachibowli	18.05	19.45	01.40	BD	Due to heavy wind and rain, Tree fallen on the 11kv line at Varun Motors	-	
11	Chanda Nagar		Madinaguda	11KV	Gachibowli	17.10	19.00	01.50	BD	Due to heavy wind and rain, 11kv Jumper cut at Sub-Station	-	
12	ESCI		NCC	11KV	Kondapur	17.18	18.58	01.40	BD	Due to heavy wind and rain	-	
13	Gachibowli		Kothaguda	11KV	Kondapur	16.30	17.50	01.20	BD	Due to heavy wind and rain	-	
14	Gachibowli		Sai baba	11KV	Kondapur	16.33	19.03	02.30	BD	Due to heavy wind and rain , 11kv Disk failed at B-block, sreeram Nagar	-	
15	Gachibowli		Gowthami Society	11KV	Kondapur	17.02	18.25	01.23	BD	Due to heavy wind and rain	-	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Madinaguda	HMT maqtha	11KV	Kukatpally	16.50	18.27	01.37	BD	11kv line Pin Insulator failure Near Panthulamma T/F , HMT maqtha	-
2		Madinaguda	FCI Colony	11KV	Kukatpally	18.15	19.37	01.22	BD	Tree branchesh Fallen the 11kv line at Siddi Vinayaka, Shanthinagar	-
3		Madinaguda	Shanthinagar	11KV	Kukatpally	17.33	19.23	01.50	BD	line AB Open siddivinayaka,{Petroling No Visble Falt}	-
4		Gagilapur	Chaitanya Colony	11KV	Jeedimetla	05.10	06.50	01.40	BD	Due to wind and rain	-
5		HMT	Venkanna Hills	11KV	Medchal	18.20	19.30	01.10	BD	Tree fallen on the 11KV Line at Modi Builders	-
6		Aliabad	LGM Pet	11KV	Medchal	01.10	03.00	01.50	BD	11KV Pin Insulator failed at Borugu Bhavi	-
7		Devarayamjal	DMC	11KV	Medchal	19.00	20.50	01.50	BD	11KV Line cut and replaced near DMC	-
1	RR E	Aushapur	Aushapur	11KV	Keesara	19.00	20.10	01.10		11KV Insulator failed near Srinidhi Resort	-
2		Singapur	RGK	11KV	Keesara	16.30	18.20	01.50		Tree branches fallen on 11KV line at RGK - 20,26,30 Blocks	-
3		Singapur	Annojiguda	11KV	Keesara	18.15	20.00	01.45		11KV Jumper cut at Annojiguda	-
1	HYD N	Toli Chowki	Road No.86	11KV	X	04.50	07.05	02.15	EL	Cable End Kit failed at Y.S.Jagan House	-
2		Madhapur	Vanen Burg	11KV	X	10.05	13.15	03.10	EL,OL-Rph	RMU failed & Twisted Lines at Ohri's Building	-
3		Bansilalpet	Hyder Basti	11KV	V	14.40	16.00	01.20	EL	Cable fault	Arranged B/F on 11KV Bata feeder
4		Monda Market	Monda Market	11KV	V	14.50	15.55	01.05	EL,OL-R&Bph	HT Jumper cut at Gandhi Nagar	-
5		Madhapur	Vanen Burg	11KV	X	16.15	19.25	03.10	EL,OL	-----	Arranged B/F on 11KV Info Tech feeder
6		Kalyan Nagar	Sri Ram Nagar	11KV	IV	17.46	18.58	01.12	EL	Pin Insulator flash over at Dhanunjay Apts	-
7		Kalyan Nagar	Krishna Nagar	11KV	X	17.24	18.28	01.04	EL	Kite Sticks fallen on lines at Rehamath Nagar	-----
8		Road No.12	Road No.12	11KV	X	18.15	19.46	01.31	EL	Tree branches fallen on lines at Road No.12	-----
9		Gymkhana	Vikrampuri	11KV	C-VI	19.21	20.28	01.07	EL	Pin Insulator flash over at Vikrampuri	-----
10		Madhapur	Vaishnavi Residency	11KV	X	18.20	19.53	01.33	EL	Tripping Coil Jumper cut & Breaker problem at SS	Arranged B/F on 11KV Kummari Basthi fdr
11		Film Nagar	Apollo	11KV	X	20.15	22.03	01.48	EL,OL-Bph	Jumper cut at Film Chamber & Coconut tree branch fallen on lines at Road No.72	-----
1	HYD S	Falaknuma	Guntal Shah Darga	11KV	III	17.05	18.45	01.40	EL	No Visible Fault	-
2		Ch' Baradari	Doodh Bowli	11KV	III	05.28	07.10	01.42	EL,OL	Cable Jumper cut at Lakdika Jamal	-
3		Kandikal Gate	G.M.Chowni	11KV	III	21.00	22.15	01.15	OL-Rph	Faulty DTR at G.M.Chowni Kamman	-
1		S.D.Hospital	Ahmed Nagar Cable	11KV	VII	04.30	06.04	01.34	EL	Jumper cut at Mustafa Masjid, Syed Ngaar	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
2	HYD C	Toli Chowki	B.S.N.L	11KV	VII	04.45	06.20	01.35	All Indication	Jumper cut at BSNL Office	-
3		A.S.R Raju Nagar	Golla Basti	11KV	VII	17.30	19.07	01.37	EL	AB Cable fault at Khaleem Hotel (2No. DTR's Kept Off)	-
4		Toli Chowki	Paramount Hills	11KV	VII	06.25	07.50	01.25	EL	Jumper cut and touching to channel at Kabarstan	-
5		Mothi Mahal	M.D Lines	11KV	VII	16.26	18.14	01.48	EL,OL-Yph	Faulty loads of 11KV Mothi Mahal feeder	-
6		Amberpet	Tilak Nagar	11KV	II	17.12	18.15	01.03	EL	Tree branches fallen on lines at 6 Number	-
7		S.D.Hospital	Crescent Hospital	11KV	VII	17.43	19.48	02.05	EL,OL	Cable Jumper cut at Crescent Hospital	-
8		Asif Nagar	Military	11KV	VII	16.30	19.30	03.00	EL,OL	Pin Insulator flash over & Tree branches fallen on lines at Military Area	-
9		I.T.I Mallepally	Indira Nagar	11KV	VII	16.22	18.50	02.28	EL,OL-Bph	Twisted HT Lines at China Bazar, Asif Nagar	-
10		Industrial Area	Azamabad I.E	11KV	II	16.40	17.55	01.15	EL	No Visible Fault	-