

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988	1	4	1	4	1	4			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>5</b>	<b>2</b>	<b>5</b>	<b>2</b>	<b>5</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>10</b>	<b>2</b>	<b>10</b>	<b>2</b>	<b>10</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 03.03.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Thomidirekula	33KV	Jadcherla	03.35	10.00	06.25	E/L	33KV Jumper Cut	Thomidirekula	-
1	NLG	Haliya	Peddavoora	33KV	Miryalaguda	07.15	09.15	02.00		Jumper Cut	Peddavoora	-

## TSSPDCL - LMRC / Corporate office

Date: 03.03.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Ravulapallu	Thurpugudem	11KV	Suryapet	14.40	16.10	01.30	EL	Bird fallen on the line	-
2		Madgulapally	Dacharam	11KV	Nalgonda	07.30	11.40	04.10	EL	11KV Insulator failed	-
3		Gurralladandi	Raipad	11KV	Bhongir	09.00	10.30	01.30	OL	11KV Jumper Cut Near Peddapalugu Thanda	-
4		Ishkilla	Kakkireni	11KV	Choutuppal	06.50	08.45	01.55	OL	11 kv Jumper Cut Near Kakkireni Village	-
1	SDP	Potharam	Nagaram	11KV	Husnabad	02.10	08.25	06.15		Jumper cut	-
1	RR N	HMT	Manikya Nagar	11KV	Medchal	07.20	07.55	00.35		11KV Disc failed at Venkateswara Nagar	-
2		Jagathgirigutta	IDA-I	11KV	Medchal	01.50	04.35	02.45		11KV Conductor Snapped at HMT Jungle	-
1	RR E	Kushaiguda	Kamala Nagar	11KV	Sainikpuri	04.35	05.15	00.40		11Kv line AB Switch opened at Kamala Nagar Due to line Patrolling Done But no fault found (LM Srinivas	-
2		Mallapur 2	AP colony	11KV	Habsiguda	12.25	13.55	01.30		Tripped on EL/OL Due to cable fail at shiva hotel	-
1	HYD S	Kandikalgate	Patel Nagar	11KV	III	10.24	13.00	02.36	OL-Rph	UG Cable fault at Asram Nagar (2No. DTR's Kept Off)	-