

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		6		6		6			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	



TSSPDCL - LMRC / Corporate office

Date: 10.03.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Dirsincherla	Dirsincherla	11KV	Huzurnagar	09.00	09.50	00.50	EL	Due to 11Kv line snapped	-
2		Keethavarigudem	Velidanda	11KV	Huzurnagar	03.50	07.00	03.10	OL	Due to bird fall on 11Kv line	-
3		T Giri	Thonda	11KV	Suryapet	13.30	14.50	01.20	EL	Jumper cut	-
4		Gurraladandi	Jampally	11KV	Bhongiri	11.30	13.00	01.30	OL	11 kv Line Cut Near Gurraladandi Sub-Stration	-
5		Sharajipeta	Saigudem	11KV	Bhongiri	09.40	13.20	03.40	OL	11 kv Line Snapped Near Saigudem Village	-
6		Chinthapally	Nasarlappally	11KV	Devatrakonda	00.00	08.00	08.00	E/L	11KV Disc Failed	-
1	MDK	Anrich Bollaram	Sulaxshana-II	11KV	Patancheru	08.36	09.20	00.44		B/D Due to Jumper Cut	-
1	HYD C	Golconda	Narayanamma College	11KV	VII	22.45	23.55	01.10	EL,OL-Bph	Cable fault at Vetarnity Colony	-