

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044	1	3	1	3	1	3			
	Total	606	3055	1	6	1	6	1	6	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		6		6		6			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	9	1	9	1	9	0	0	
	Grand Total	1082	6468	2	15	2	15	2	15	0	0	

TSSPDCL - LMRC / Corporate office

Date: 15.03.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Pashamailaram	Manjeera	33kv	Sangareddy	08.30	10.50	02.20		BD due to Dish cable fallen on line	Manjeera	-
1	HYD S	220KV Shivrampally	Hyderguda	33kv	Asmangadh	16.20	16.40	00.20	EL,OL	Cable damaged by Master Plan wing near Upperpally Court	Hyderguda	Loads transferred onto 220KV Shivrampally SS via 33KV Karwan OH feeder

TSSPDCL - LMRC / Corporate office

Date: 15.03.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Thirmalapur	Dondiapally	11kv	Jadcherla	12.41	15.00	02.19		Phase to Phase near puthina pally.	-
1	NLG	Reddygudem	Gorentla	11kv	Suryapeta	04.00	06.48	02.48	E/L	Insulator failure	-
2		Thogarrai	Ganapavaram	11kv	Huzurnagar	05.00	08.00	03.00	E/L	Jumper cut	-
3		Thogarrai	Kuchipudi	11kv	Huzurnagar	11.50	14.00	02.10	E/L	Jumper cut	-
4		Aregudem	Peddakaparthu	11kv	Nalgonda	10.30	12.30	02.00	E/L	HT/LT Line melting	-
5		Cherukupally	Dacharam	11kv	Nalgonda	08.00	10.30	02.30	E/L	Insulator failure	-
6		D.Nagaram	D.Nagaram AGL	11kv	Bhongiri	08.35	09.50	01.15	E/L	Jumper cut	-
1	MDK	Gaddapotharam - I	Kekule	11kv	Patancheru	12.25	18.25	06.00		BD due to Underline cable failed	-
2	SDPT	Pandilla	Potlapally	11kv	Husnabad	09.00	10.00	01.00		AB Switch Repaire	-
1	RR S	L&T	PJR Nagar	11kv	GCB	14.25	17.20	02.55	BD	11KV UG Cable Damaged near Outer Ring Road at Gachibowli.	-
1	RR N	GP Pally	GP Pally	11kv	Medchal	12.10	12.50	00.40		11KV Pin Insulator failed near Ayodhya Chowrasta	-
1	RR E	Pocharam	Jodimetla	11KV	Keesara	15.30	16.06	00.36		11KV Line cut at Jodimetla Sai Vani Grammer School	-
1	HYD N	Chinna Thokatta	Panchavati Colony	11KV	VI	08.42	10.10	01.28	EL,OL-Y&Bph	2No. Disc Insulators flash over & 3No. Jumpers cut at Ashok Garden	-----
2		Madhapur	Durgam Cheruvu	11KV	X	12.30	14.30	02.00	EL,OL-Rph	Cable damaged at SS	-----
3	HYD S	S.D.Hospital	Police Mess	11KV	VII	11.44	13.05	01.21	EL	DTR fault at last line AB Switch	Arranged B/F on 11KV Ahmed Nagar OH feeder