

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		8		8		8			
3	MDK	107	933									
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	11	0	11	0	11	0	0	
	Grand Total	1082	6468	0	11	0	11	0	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.03.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Alingapuram	Gundlapahad	11KV	Huzurnagar	07.50	09.00	01.10	EL	Due to 11Kv line snapped	-
2		Nadigudem	Ramapuram	11KV	Huzurnagar	10.10	13.20	03.10	EL	Due to 11Kv jumper cutted	-
3		Indloor	Vaderigudem	11KV	Nalgonda	08.47	11.36	02.49	EL	Insulator Fail	-
4		Kattangur	Dugunavelly	11KV	Nalgonda	06.30	09.43	03.13	EL	11KV Line Disk Near By Village	-
5		Pulimamidi	Haliya	11KV	Miryalaguda	09.30	12.30	03.00	EL	11KV Jumper cut near village	-
6		Brundavanapuram	Tripuraram	11KV	Miryalaguda	07.40	09.45	02.05	EL	11KV pin insulator failed at Brundavanapuram	-
7		Choutupal	Thagadapally	11KV	Choutupal	08.35	12.50	04.15	OL	Jumper Cut	-
8		D.Nagaram	Loth Lab	11KV	Choutupal	08.30	10.00	01.30	OL	Noth Lab Company DTR Fuse Fail	-
1	SDP	Bejjanki	Kallepally	11KV	Siddipet	13.10	17.10	04.00		Bunch cable cut	-
2		Begumpet	Begumpet Rural	11KV	Siddipet	16.10	17.10	01.00		Break down	-
3		Mustyal	Salakpoor	11KV	Siddipet	06.40	08.15	01.35		Conductor snapped	-