

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	6	0	6	0	6	0	0	
	Grand Total	1082	6468	0	10	0	10	0	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 18.03.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Angadipeta	Akkampally	11KV	Devarakonda	06.40	07.40	01.00	E/L	Jumper cut	-
2		Angadipeta	R.R.Gudem	11KV	Devarakonda	10.30	12.10	01.40	E/L	11KV Line cut	-
3		Marriguda	Vattipally	11KV	Devarakonda	03.40	09.20	05.40	E/L	11KV Line cut	-
4		Palakeedu	Palakeedu	11KV	Huzurnagar	06.00	08.15	02.15	E/L	11KV Line Snapped	-
1	SDP	Dharmaram	Nandaram	11KV	Husnabad	12.10	14.10	02.00		11KV Conductor snapped	-
2		Pandilla	Kunchanpally	11KV	Husnabad	17.00	18.45	01.45		Conductor snapped	-
1	RR S	Upparpally-II	Fortview colony	11KV	RJNR	07.10	08.20	01.10	B/D	11kv UG Cable Failed at Fortview colony Main Road	-
1	RR E	Kushaiguda	Kapara	11KV	Sainikpuri	20.50	21.20	00.30		Tree branches fallen on 11Kv line at Sri Nagar Colony (AE)	-
1	HYD N	Madhapur	Vaishanavi Residency	11KV	X	03.05	05.00	01.55	EL,OL	Cable fault near TCS	Arranged B/F on 11KV Kummari Basti feeder
2		Raheja	Gafoor Nagar	11KV	X	04.24	06.30	02.06	OL-Rph	Road crossing Cable fault at Gafoor Nagar	Arranged B/F on 11KV Gowra feeder