

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		7		7		7			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	8	0	8	0	8	0	0	
	Grand Total	1082	6468	0	8	0	8	0	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 19.03.19

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Molkapatnam	Molkapatnam	11KV	Miryalguda	13.30	15.00	01.30	E/L	11Kv Jumper cut near (v)	No
2		Mudigonda	Gottimukala	11KV	Devarakonda	06.40	07.00	00.20	E/L	11Kv Jumper Cut	No
3		Thungathurthy	Banda Ramaram	11KV	Suryapet	05.05	07.35	02.30	E/L	11Kv Conductor snapped	No
4		N.B.Gudem	Redlakunta	11KV	Huzurnagar	4:00	6:00	2:00	E/L	11Kv Jumper Cut	No
5		Bheelya Naik thanda	Pathathanda	11KV	Huzurnagar	05.25	08.30	03.05	E/L	11Kv Jumper Cut	No
6		Gondriyala	Chimiryala	11KV	Huzurnagar	12:02	14:26	2:24	E/L	11Kv Conductor snapped	No
7		Choutuppal	RR.Metal Indl	11KV	Choutuppal	14.06	15.35	01.29	E/L	HT/LT near Lingo jigudem (V)	No
1	MDK	Nasthipur	Industrial	11KV	Jogipet	13:25	14:45	1:20		Insulator failed	No