

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		4		4		4			
3	MDK	107	933	2	2	2	2	2	2			
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	8	3	8	3	8	0	0	
	Grand Total	1082	6468	3	11	3	11	3	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 21.03.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Gadwal	Bijwaram	33KV	Gadwal	04.35	11.05	06.30	E/L	for Conductor snapped near Sangal	Bijwaram	-
1	MDK	Sadashivapet	Munipally	33KV	Sangareddy	13.40	14.15	00.35		B/D due to Tree branches fallen on the line	Munipally	-
2		Bollaram	VIF	33KV	Patancheru	11.15	14.30	03.15		B/D due to Jumper cut	VIF	-

TSSPDCL - LMRC / Corporate office

Date: 21.03.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Penpahad	Potlapahad	11KV	Suryapeta	11.25	13.00	01.35	E/L	Bird fallen on the line	-
2		Akkaram	Vadipamula	11KV	Nalgonda	14.20	16.10	01.50	E/L	11 KV Line Disc Failure	-
3		Ch,Annaram	Thotlavarigudem	11KV	Nalgonda	09.05	11.00	01.55	E/L	11 KV Jumper Cut	-
4		Kattangur	Bollepally	11KV	Nalgonda	16.00	17.50	01.50	E/L	11 KV AB Switch Fimal Fail	-
1	MDK	SOL	IDA-II	11KV	Patancheru	01.05	03.00	01.55		B/D due to Jumper cut	-
2		Ismailkhanpet	Ismailkhanpet	11KV	Sangareddy	08.10	09.25	01.15		B/D due to Jumper cut	-
1	SDPT	Gandiapally	Gandiapally	11KV	Husnabad	11.55	12.20	00.25		AB switch failure	-
2		Rebarthy	Rebarthy	11KV	Husnabad	11.35	16.50	05.15		Jumper cut	-
1	RR N	Dp pally	Gagillapur	11KV	Jeedimetla	14.50	16.50	02.00	OL	11kv Line Cut at Dundigal	-
1	RR E	Malkajgiri	Anandbagh	11KV	Sainikpuri	03.28	04.04	00.36		Lezard fallen on 11Kv line 100Kv T/F at Street No 2 Vani Nagar (Artisan/Balreddy)	-
1	HYD S	Falaknuma	Chatrinaka	11KV	III	02.15	04.13	01.58	EL	Cable fault at Chatrinaka	Arranged B/F on 11KV G M Chowni & Gowlipura fdrs