

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044	1		1		1				
	Total	606	3055	1	0	1	0	1	0	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	1	6	1	6	1	6			
3	MDK	107	933		2		2		2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	8	1	8	1	8	0	0	
	Grand Total	1082	6468	2	8	2	8	2	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 25.03.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Ramannapet	Yellanki	33KV	Choutuppal	16.26	17.35	01.09	OL	33 kv Lighting Arrester Fail in 33 kv Yellanki Sub Station	Yellanki	-
1	HYD S	220KV Shivrampally	Miralam	33KV	Malakpet	17.45	17.55	00.10	EL,OL-Yph	No visible fault	Miralam	Loads transferred onto 33KV Shivrampally - Ch' Baradari OH feeder

TSSPDCL - LMRC / Corporate office

Date: 25.03.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Arlagadda Gudem	Mangalapally	11KV	Nalgonda	03.30	07.10	03.40	EL	11 KV Line Cut	-
2		Mamidala	Mamidala	11KV	Nalgonda	10.38	12.03	01.25	EL	11 KV Line Jumper Cut	-
3		Rajavaram	JC thanda	11KV	Mirylaguda	09.36	12.00	02.24	EL	Line Cut & 10KVA DTR problem	-
4		Kudakuda	Kuda kuda Agl	11KV	Suryapet	07.00	09.45	02.45	EL	Insulator failed	-
5		Karivirala	Ramchandrapuram	11KV	Huzurnagar	06.00	09.00	03.00	EL	Due to tree branch fallen on line	-
6		Paladugu	Paladugu	11KV	Bhongir	15.10	16.30	01.20	EL	11 kv Insulator Failed Near Palleria Village	-
1	MDK	Waddepally	Industrial	11KV	Jogipet	05.00	10.00	05.00		B/D Due to Conductor Snapped	-
2		Munipally	Budhera	11KV	Sangareddy	15.45	18.26	02.41		B/D Due to Conductor Snapped	-