

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044									
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		5		5		5			
3	MDK	107	933		3		3		3			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>8</b>	<b>1</b>	<b>8</b>	<b>1</b>	<b>8</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 26.03.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Solipur	33KV	Wanaparthi	15.45	18.18	02.33	EL	No Visible Fault	Solipur	No

## TSSPDCL - LMRC / Corporate office

Date: 26.03.19

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kodur	Kodur	11KV	Suryapeta	4:00	6:45	2:45	E/L	Insulator failed	No
2		Narsingbatla	Kuthurugudem	11KV	Nalgonda	14.30	17.05	02.35	E/L	11KV Line Disc failed	No
3		Palivela	Ipparthy	11KV	Nalgonda	10.38	12.03	01.25	E/L	11KV Line Jumper cut	No
4		Dilchinchera	Yellapuram	11KV	Huzurnagar	08.30	10.00	01.30	E/L	11KV Line Jumper cut	No
5		Mukundapuram	Mukundapuram	11KV	Huzurnagar	6:30	9:20	2:50	E/L	11KV Line Jumper cut	No
1	MDK	Pati	My Home	11KV	Patancheru	7:30	8:50	1:20		11KV Jumper Cut	No
2		Kistareddypet	Industrial	11KV	Patancheru	09.15	09.50	00.35		11KV Jumper Cut	No
3		Bollaram - II	Shalini	11KV	Patancheru	09.52	13.20	03.28		Conductor Snapped	No
1	RR N	Nizampet	Journalist Colony	11KV	Kukatpally	19:14	20:40	1:26	EL	No visible fault	No