

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044	1	1	1	1	1	1			
	Total	606	3055	1	2	1	2	1	2	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	8	0	8	0	8	0	0	
	Grand Total	1082	6468	1	10	1	10	1	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 27.03.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	HYD N	132KV Gunrock	Bhudevi Nagar	33KV	Nehrunagar	11.30	11.36	00.06	EL,OL	CT Blast at 132KV Gunrock	Bhudevi Nagar	Loads transferred onto 132KV Gunrock SS via H.M.T SS

TSSPDCL - LMRC / Corporate office

Date: 27.03.19

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kollur	Navabpet	11KV	Jadcherla	10.30	12.45	02.15		Tree fallen on 11KV line near Jangamaiah pally.	No
1	NLG	Arlagaddagudem	N.R.Gudem	11KV	Nalgonda	14:00	17:30	03.30	E/L	Insulator failed	No
2		Ramachandrapuam	Rathnapuram	11KV	Suryapet	06.00	08.45	02.45	E/L	Insulator failed	No
3		Gondriyala	Chimiryala	11KV	Huzurnagar	14.00	17.00	03.00	EL	Jumper cut	No
4		Ananthagiri	Shantinagar	11KV	Huzurnagar	14.00	16.00	02.00	EL	Jumper cut	No
1	SDPT	Gandiapally	Gandiapally	11KV	Husnabad	15:35	16:20	00.45		33 KV line touch in 11 KV Line	No
2		Bejjanki	Muthannapet	11KV	Husnabad	01.15	09.00	08.45		Line cut	No
3		Nagapuri	Gandikunta	11KV	Husnabad	10.20	10.35	00.15		33 kV line touch in 11 KV Line	No
1	RR N	Jeedimetla-III	USP Organic	11KV	Jeedimetla	16:40	18:10	01.30		UG Cable End kit failure at SS Yard	No
1	HYD C	Vittalwadi	Gandhi Kuteer	11KV	Azamabad	02.02	03.18	01.16	EL,OL-R&Bph	Breaker problem at SS	Arranged B/F on 11KV APCO fdr