

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044		20		20		20			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>28</b>	<b>0</b>	<b>28</b>	<b>0</b>	<b>28</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		4		4		4			
3	MDK	107	933	2	1	2	1	2	1			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>3</b>	<b>6</b>	<b>3</b>	<b>6</b>	<b>3</b>	<b>6</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>3</b>	<b>34</b>	<b>3</b>	<b>34</b>	<b>3</b>	<b>34</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 31.03.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Mahabubnagar	33KV	Bhoothpur	22.35	22.48	00.13	EL	Pin banding failure near by Town3 SS AE/OP/Town3	Mahabubnagar	Alternate Supply Arranged from 33KV Nawabpet feeder at 22:48Hrs
1	MDK	Kandi	BDL	33KV	Sangareddy	17.15	22.10	04.55	B/D due to Conductor sanpped	BDL		-
2		Gummadidal	Dundigal	33KV	Patancheru	20.40	21.23	00.43	B/D due to Jumper cut	Dundigal		-

## TSSPDCL - LMRC / Corporate office

Date: 31.03.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Yerkaram	Ramannagudem	11KV	Suryapet	10.05	11.20	01.15	EL	Insulator failed	-
2		Karivirala	Ramachandrapuram	11KV	Huzurnagar	07.50	09.15	01.25	EL	11 KV LINE SNAPPED	-
3		Anantharam	Manchukonda Indl	11KV	Bhongiri	11.15	13.00	01.45	EL	Fault Not Rectified. Alternate Supply Taken Bibinagar Sub Station	-
4		Pamukunta	Singaram	11KV	Bhongiri	10.35	11.15	00.40	OL	11 KV Jumper Cut Near Singaram Village	-
1	MDK	Sangareddy -I	Nalsabgada	11KV	Sangareddy	22.40	23.40	01.00		B/D due to Insulator fail.	-
1	SDP	Gouravelly	Gudatipally	11KV	Siddipet	01.35	12.10	10.35		Line snapped and same rectified	-
1	RRS	Gaganpahad	NPA(GPHD)	11KV	RJNR	16.23	17.57	01.34		No Visible Fault	-
1	RR N	UMCC	Crusher	11KV	Medchal	21.10	21.50	00.40	BD	No Fault	-
2		UMCC	Gajularamaram	11KV	Medchal	21.10	22.38	01.28	BD	Tree fallen on the 11KV Line at Sriveni Enclave	-
3		Subhash Nagar	Gayatri Nagar	11KV	Medchal	21.50	22.23	00.33	BD	No Fault	-
4		Subhash Nagar	Meenakshi	11KV	Medchal	22.00	00.40	02.40	BD	Tree fallen on the 11KV at Satyam Enclave	-
1	RR E	Vinayak Nagar	Old Safilguda	11KV	Sainikpuri	21.42	22.30	00.48		11Kv Pin Insulator failed at Vinayak Nagar Block No.3 (AE/OP)	-
2		Mallapur-2	Surya Nagar	11KV	Habsiguda	21.35	22.40	01.05		11KV HG Fuse Insulator failed at Mallikarjuna Nagar	-
3		Mallapur-2	Ashok Nagar	11KV	Habsiguda	21.55	23.00	01.05		11KV Disc failed near Tent House T/F at Ashok Nagar	-
1	HYD N	Gunrock	Gymkhana	11KV	V	21.32	22.45	01.13	EL,OL-Rph	Brass Patti cut at AWHO	-
2		Gunrock	Anjaia Nagar	11KV	VI	21.30	22.50	01.20	EL	Tree Branches fallen on lines at Govt.School	-
3		Gunrock	Lal Bazar	11KV	C-VI	21.25	22.35	01.10	EL	Jumper cut at 1st line AB Switch	-
4		Thirumalgiri	Khanajiguda	11KV	VI	21.40	00.06	02.26	EL	Bird fault at Khanajiguda	-
5		Yousufguda	Hylom Colony	11KV	X	20.45	22.20	01.35	EL,OL	No Visible Fault	-
6		Yellareddyguda	Savera	11KV	X	20.40	21.45	01.05	EL	No Visible Fault	-
7		Srinagar Colony	Satya Sai	11KV	X	20.58	22.15	01.17	OL-Rph	Tree Branches fallen on lines at SBH	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD S	Seetharam Bagh	Aghapura	11KV	IX	23.42	02.10	02.28	EL,OL-Rph	AB Cable Burnt out at Aghapura	-
1	HYD C	Fever Hospital	C.C Shroff Hospital	CEN	II	00.05	01.38	01.33	EL,OL	Cable fault	Arranged B/F on 11KV YMCA feeder
2		Fever Hospital	Tourist Hotel	CEN	II	20.48	21.55	01.07	EL,OL-Rph	No Visible Fault	-
3		Industrial Area	Azamabad Key SS	CEN	II	20.50	22.00	01.10	EL,OL	No Visible Fault	-
4		Vittalwadi	Gandhi Kuteer	CEN	II	20.55	22.35	01.40	All Indication	Jumper cut at Melkoti Park	-
5		Batkammakunta	C.E.Colony	CEN	II	20.58	22.35	01.37	EL	DTR fault at Nandaraj Garden	-
6		Batkammakunta	C.E.Colony	CEN	II	23.22	00.42	01.20	OL-Rph	HG fuse B/O at Nandaraj Goud DTR	-
7		Industrial Area	RTC X Roads	CEN	II	23.15	00.30	01.15	EL,OL-Yph	Dog fallen on DTR at RTC X Road	-
8		Amberpet	C.P.L	CEN	II	23.27	00.55	01.28	EL	Pin Insulator flash over at Patelwada	-
9		Narayanguda	City Central Library	CEN	I	20.45	22.05	01.20	EL	No Visible Fault	-
10		Erra Manjil	Jafar Ali Bagh	CEN	I	22.00	23.49	01.49	EL	No Visible Fault	-
11		Nizam College	Brand Factory	CEN	I	20.59	22.29	01.30	EL,OL-Rph	No Visible Fault	-
12		I.T.I Mallepally	Indira Nagar	CEN	VII	23.27	00.30	01.03	EL	AB Cable fault at OYC Park	-