

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044	1	1	1	1	1	1			
	Total	606	3055	1	2	1	2	1	2	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		9		9		9			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	9	0	9	0	9	0	0	
	Grand Total	1082	6468	1	11	1	11	1	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 04.05.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	HYD C	220KV Shivrampally	Karwan	33KV	Asif Ngr	00.35	00.43	00.08	EL,OL	Cable End Kit failed at 33KV Karwan SS	Karwan	Loads transferred onto 132KV Imlibun SS via 33KV Jiyaguda SS (From 15.16 to 15.19 hrs Loads normalised)

TSSPDCL - LMRC / Corporate office

Date: 04.05.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Aalagada Gudem	N.R.Gudem	11KV	Nalgonda	14.20	17.20	03.00	E/L	11 KV Line Cutt	-
2		P.D.Pally	P.D.Pally	11KV	Nalgonda	12.15	14.10	01.55	E/L	HT/LT Line Cutt	-
3		Ch.Annaram	Garalabhai Gudem	11KV	Nalgonda	08.15	12.20	04.05	E/L	Ht/LT	-
4		IDA	Bommaipally	11KV	Bhongir	12.16	15.22	03.06	EL	11 KV Disc Failed Near Bommaipally Village	-
5		IDA	Singannagudem	11KV	Bhongir	12.40	15.22	02.42	OL	HT/LT at Singannagudem Near Bhongir Town	-
6		Peddathanda	Peddathanda	11KV	Bhongir	07.45	12.50	05.05	EL	25 kva DTR off at Choklathanda Near Rusthapur Village	-
7		Ramlingampally	Ramlingampally	11KV	Bhongir	12.30	16.15	03.45	EL	11 kv Pin Insulator Failed Near Ramlingampally Village	-
8		Golankonda	Matoor	11KV	Bhongir	15.00	17.35	02.35	EL	Jumper open at Sharbanapuram Village Line Stand . 10 DTR's OFF	-
9		S.Lingotam	Indl	11KV	Choutuppal	08.00	09.41	01.41	EL	Moment Fault	-
1	RR N	Kompally	Kompally	11KV	Medchal	13.50	14.20	00.30	BD	100KVA T/F AB Cable failed at Grama Panchayathi	-
1	HYD C	Vittalwadi	Basanth Colony	11KV	II	16.00	17.20	01.20	All Indication	Standby Cable fault at Nrupathunga College	-