

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044	1	2	1	2	1	2			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>1</b>	<b>4</b>	<b>1</b>	<b>4</b>	<b>1</b>	<b>4</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	1	2	1	2	1	2			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>3</b>	<b>1</b>	<b>3</b>	<b>1</b>	<b>3</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>7</b>	<b>2</b>	<b>7</b>	<b>2</b>	<b>7</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 05.05.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Shaligowraram	Nakrekal	33KV	Nalgonda	10:25	15:45	5:20		2 Discs failed		
1	HYD C	132KV Asif Nagar	Seetharambagh	33KV	Asif Ngr	11.35	11.50	00.15	OL-Rph	Cable fault at opp. Venkateshwara Wines, Gudimalkapur	Seetharambagh	Loads transferred onto 132KV Asif Nagar SS via 33KV Seetharam Bagh OH fdr

TSSPDCL - LMRC / Corporate office

Date: 05.05.19

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Annaram	Annaram	11KV	Suryapet	12:05	14:00	01.55	EL	Insulator failed	No
2		Y.Gutta	Saidapur	11KV	Bhongir	09.00	11.00	02.00	EL	Jumper open near Wangapally	No
1	MDK	Bollaram-I	Aurobindo	11KV	Patancheru	6:50	7:20	0:30		Jumper cut	No
1	RR S	MD Pally	Laxmiguda	11KV	Rajendranagar	01.25	02.53	01.28		Flex banners fallen on 11KV line at Prakash goud MLA House	No
2		Upparpally-II	Parmareddy hills	11KV	Rajendranagar	14.30	15.53	01.23		11KV Cable failed at Pillar No-179 due to JCB digging work	B/F Given to 11KV RTA Office
1	HYD N	Gymkhana	Balamrai	11KV	Bowenpally	17.20	18.50	01.30	EL,OL-Bph	Cable fault at Balamrai	Arranged B/F on 11KV Rani Bagh fdr
2		Srinagar Colony	Kamalapuri Colony	11KV	Banjarahills	18:02	20:13	2:11	EL	AB Cable End Kit failed at Kamalapuri Colony Park	No