

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	1	2	1	2	1			
2	NLG	144	988		8		8		8			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	9	2	9	2	9	0	0	
	Grand Total	1082	6468	2	12	2	12	2	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 09.05.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Midjil	Midjil	33kv	Jadcherla	11.15	12.20	01.05	OL	No Visible Fault	Midjil	-
2		Wanaparthi	Kodair	33kv	Wanaparthi	03.38	05.45	02.07	OL	No Visible Fault	Kodair	-

TSSPDCL - LMRC / Corporate office

Date: 09.05.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothamolgara	Maddigatla	11kv	Jadcherla	03.00	07.00	04.00		B.D.11Kv Conductor Cut Near Nallagutta Side.	-
1	NLG	Penpahad	Annaram	11kv	Suryapet	13.15	16.00	02.45	EL	SS-4 Jumper cut	-
2		Garidepally	Ponugodu	11kv	Huzurnagar	04.50	07.00	02.10	EL	11 KV LINE SNAPPED	-
3		Munagala	Nelamarri	11kv	Huzurnagar	18.50	21.00	02.10	EL	11 KV LINE SNAPPED	-
4		Dirincherla	Narsaigudem	11kv	Huzurnagar	08.30	10.00	01.30	EL	11 KV LINE SNAPPED	-
5		Koppole(K)	Beemavaram	11kv	Nalgonda	13.45	16.30	02.45	E/L	11KV Line Cut	-
6		Mondollagudem	Nelapatla AGL	11kv	Choutuppal	11.05	13.15	02.10	E/L	11KV Pole Damaged	-
7		Pamulapad	Pamulapad	11kv	Miryalaguda	12.07	14.15	02.08	E/L	11KV Jumper cut near village	-
8		V K Palem	Thungapad	11kv	Miryalaguda	15.00	16.45	01.45	E/L	11KV line snapped near Thungapad bridge	-
1	RR N	Dppally	IDA Gagillapur	11kv	Jeedimetla	07.24	10.05	02.41	BD	11kv line Cut at Mallanna Temple ,Gagillapur	-
1	HYD C	Chilalguda	Parsigutta	11kv	Saifabad	13.45	15.15	01.30		HT line snapped at parsigutta	-
2		S.D.Hospital	Humayunnagar	11kv	Saifabad	22.43	00.05	01.22		Due to end kit failed	-