

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044		6		6		6			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>12</b>	<b>0</b>	<b>12</b>	<b>0</b>	<b>12</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	5	2	5	2	5	2			
2	NLG	144	988	8	47	8	47	8	47			
3	MDK	107	933	1	2	1	2	1	2			
4	SDPT				5		5		5			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>14</b>	<b>56</b>	<b>14</b>	<b>56</b>	<b>14</b>	<b>56</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>14</b>	<b>68</b>	<b>14</b>	<b>68</b>	<b>14</b>	<b>68</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

Date: 12.05.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Kankurthy	33KV	Narayanapet	20.30	20.45	00.15	EL	33KV Insulator failed	Kankurthy	No
2		Ghanapur	Lattupally	33KV	Wanaparthy	09.27	10.15	00.48	EL	No Visible fault	Lattupally	No
3		Wanaparthy	Kodair	33KV	Wanaparthy	06.04	09.10	03.06	EL	33KV Conductor snapped near Appaipally Tanda	Kodair	No
4		Nagarkurnool	Bijinepally	33KV	Nagarkurnool	5:15	8:10	2:55	EL	Pin insulator failed	Bijinepally	No
5		Kothur	PNG	33KV	Shadnagar	03.40	08.55	05.15	EL	Replacement of Cable Kit at Company	PNG	No
1	NLG	Suryapet	Nemmikal	33KV	Suryapet	0:00	5:30	5:30	E/L	Disc Flashover	Nemmikal	No
2		Suryapet	Chivemla	33KV	Suryapet	00.00	01.20	01.20	E/L	Insulator flashover	Chivemla	No
3		Suryapet	Yerkaram	33KV	Suryapet	11.40	14.10	02.30	O/L	Disc Flashover	Yerkaram	No
4		Kodad	Kodad	33KV	Huzurnagar	18.10	22.50	04.00	EL/OL	33 KV INSLATER FAILED	Kodad	No
5		Dirincherla	Mukundapuram	33KV	Huzurnagar	06.00	09.30	03.30	EL/OL	33 KV POLE DAMAGED	Mukundapuram	No
6		Munagala	Bethavolu	33KV	Huzurnagar	18.10	22.40	03.50	EL/OL	33 KV LINE SNAPPED	Bethavolu	No
7		Shaligouraram	Nakirekal	33KV	Nalgonda	17.20	09.20	16.00	E/L	33KV Line Cutting At Near By Vallala Villege	Nakirekal	No
8		Kolanpaka	Suddala	33KV	Bhongir	6:20	10:10	3:50	EL	Tree Branchess Fallen at Line Near Suddala Village	Suddala	No
1	MDK	Gummadidala	GPSS-2	33KV	Patancheru	11:57	16:05	4:08		Conductor snapped	GPSS-2	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Navabpet	Lokirev	11KV	Jadcherla	10.00	12.00	02.00		11KV wire cut near lokirev.	No
2		Marikal	Malkapur	11KV	Jadcherla	09.20	12.25	03.05		11KV wire cut near malkapur.	No
1	NLG	Indl.Estate	Estate	11KV	Suryapet	11:00	15:25	4:25	E/L	Pole Damaged & Tree branch fallen on the line	No
2		D.Nagaram	Wardhamanu kota	11KV	Suryapet	07.30	10.15	02.45	E/L	Insulator failed	No
3		Durajpally	Durajpally	11KV	Suryapet	02.30	07.00	04.30	E/L	Pole Damaged	No
4		Bibigudem	Munya thanda	11KV	Suryapet	03.00	08.00	05.00	E/L	Pole Damaged	No
5		Athmakur(S)	Athmakur Agl	11KV	Suryapet	06.45	11.00	04.15	E/L	Pole Damaged	No
6		Thungathurthy	Ganugubanda	11KV	Suryapet	05.00	10.00	05.00	E/L	Conductor snapped	No
7		Koduru	Kommala	11KV	Suryapet	02.00	07.30	05.30	E/L	Insulator failed	No
8		Reddygudem	Kothagudem	11KV	Suryapet	04.00	10.05	06.05	E/L	Pole Damaged	No
9		Dirincherla	Narsigudem	11KV	Huzurnagar	05.00	08.30	03.30	EL	11 KV LINE SNAPPED	No
10		Palakeedu	Palakeedu	11KV	Huzurnagar	06.00	08.45	02.45	EL	11 KV LINE SNAPPED	No
11		Garidepally	Appannapet	11KV	Huzurnagar	07.20	10.20	03.00	EL	11 KV Jumper cut	No
12		Huzurnagar-2	Lingagiri	11KV	Huzurnagar	05.00	08.00	03.00	EL	11 KV LINE SNAPPED	No
13		BNL Thanda	BNL Thanda	11KV	Huzurnagar	06.30	09.00	02.30	EL	11 KV INSLATER FAILED	No
14		Edulur	Parada	11KV	Nalgonda	20.00	14.00	18.00	E/L	Heavy Gale And Wind Tree Fail On The Line	No
15		Edulur	Munukuntla	11KV	Nalgonda	20.00	14.35	18;35	E/L	Heavy Gale And Wind Tree Fail On The Line	No
16		Palem	Ogodu	11KV	Nalgonda	09.30	11.00	01.30	E/L	11KV Line Jumper Cutting	No
17		Arlagaddagudem	N.R.Gudem	11KV	Nalgonda	20.00	14.10	18.10	E/L	Heavy Gale And Wind Tree Fail On The Line	No
18		Pamangundia	Yerrasanigudem	11KV	Nalgonda	08.40	11.40	03.00	E/L	11KV Line Insulator Failur	No
19		Thoragal	Thangallavaridudem	11KV	Nalgonda	05.30	10.00	05.30	E/L	Tree Branches On The Line	No
20		Thoragal	Thoragal	11KV	Nalgonda	05.00	10.20	05.20	E/L	11KV Line Jumper Cutting	No
21		Thoragal	Gajendrigudem	11KV	Nalgonda	05.40	11.30	06.30	E/L	11KV Line Disc Failur	No
22		Madgulapally	Dacharam	11KV	Nalgonda	18.10	09.20	15.10	E/L	Heavy Gale And Wind Tree Fail On The Line	No
23		Madgulapally	Indugula	11KV	Nalgonda	18.10	10.30	16.30	E/L	Heavy Gale And Wind Tree Fail On The Line	No
24		Madgulapally	Kukkadam	11KV	Nalgonda	18.10	11.10	17.10	E/L	Heavy Gale And Wind Tree Fail On The Line	No
25		Palivela	Palivela	11KV	Nalgonda	18.00	08.00	14.00	E/L	Heavy Gale And Wind Tree Fail On The Line	No
26		Palivela	Ipparthy	11KV	Nalgonda	18.10	09.30	15.20	E/L	Heavy Gale And Wind Tree Fail On The Line	No
27		Nakirekal	Kadaparthly	11KV	Nalgonda	20.00	11.00	15.00	E/L	Heavy Gale And Wind Tree Fail On The Line	No
28		Nakirekal	Chandampally	11KV	Nalgonda	20.00	11.15	15.15	E/L	Heavy Gale And Wind Tree Fail On The Line	No
29		Nakirekal	Chandubatla	11KV	Nalgonda	16.25	15.15	23.10	E/L	Heavy Gale And Wind Tree Fail On The Line	No
30		Nakirekal	Marrur	11KV	Nalgonda	20.15	11.00	14.45	E/L	Heavy Gale And Wind Tree Fail On The Line	No
31		Thipparthy	Marriguda	11KV	Nalgonda	07.00	10.30	03.30	E/L	11KV Line Jumper Cutting	No
32		Thipparthy	Sarvaram	11KV	Nalgonda	06.00	09.00	03.00	E/L	11KV Line Cutting	No
33		Shaligouraram	Kondram	11KV	Nalgonda	04.00	08.00	04.00	E/L	11KV Line Cutting	No
34		Shaligouraram	Adloor	11KV	Nalgonda	06.00	12.20	06.20	E/L	Tree Branches On The Line	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
35		Wangamarthy	Madaram	11KV	Nalgonda	18.00	08.00	14.00	E/L	Heavy Gale And Wind Tree Fail On The Line	No	
36		Wangamarthy	Chithaloor	11KV	Nalgonda	18.00	09.00	15.00	E/L	Heavy Gale And Wind Tree Fail On The Line	No	
37		Padamtally	Kandukur	11KV	Devarakonda	06.00	09.30	03.30	E/L	11 KV Jumper Cutt	No	
38		Bhongir	Meenanagar	11KV	Bhongir	23.25	01.47	02.22	OL	11 kv Line Snapped at Thatha nagar Near Bhongir Town	No	
39		Thukkapur	Ghouse nagar	11KV	Bhongir	08.00	11.00	03.00	EL	11 kv Insulator Failed Near Ghousenagar Village	No	
40		Peddathanda	Peddathanda	11KV	Bhongir	02.00	05.30	03.30	OL	1No LT Pole Dammaged at Piryathanda	No	
41		Maryala	Wadaparthly	11KV	Bhongir	07.00	12.30	05.30	OL	11kv Line Snapped, 11 KV Jumper cut & Phase to Phase Near Wadaparthly Village	No	
42		Motakondur	Motakondur Agl	11KV	Bhongir	02.00	08.30	06.30	OL	4 no's 11 KV Pole Dammaged &11 Line Snapped at Sikindernagar Near Motakondur Village	No	
43		Motakondur	Vartoor	11KV	Bhongir	02.00	08.15	06.15	EL	1 no. 11 KV Pole Dammaged &Tree Branchess Fallen at Line Near Vartoor Village	No	
44		Chamapur	Chamapur	11KV	Bhongir	06.00	10.30	04.30	EL	11 KV Post-off Insulator Failed Near Chamapur Village	No	
45		Panthangi	Panthangi Agl	11KV	Choutuppal	04.00	10.38	06.38	EL	11 kv Insulator Failed near Katarevu Village	No	
46		Jublakpally	Jublakpally	11KV	Choutuppal	02.00	06.15	04.15	EL	11 kv Pin Insulator Failed Near Jublakpally Village	No	
47		Aroor	Gurnathpally	11KV	Choutuppal	11:00	13:00	2:00	EL	11 kv Disc Failed Near Gurnathpally Village	No	
1		MDK	Pati	Pati	11KV	Patancheru	18:40	20:50	2:10		Conductor snapped	No
2			Sadashivapet	Kambalapally	11KV	Sangareddy	10.24	12.39	02.15		Jumper cut	No
1		SDPT	Gandipally	Ramavaram	11KV	Husnabad	3:30	3:50	0:20		Insulator failed	No
2			Gandipally	Ramavaram	11KV	Husnabad	08.40	10.25	01.45		Insulator failed	No
3	Gandipally		Ramavaram Exp	11KV	Husnabad	00.02	07.30	07.28		Insulator failed	No	
4	Gouravelly		Gudatipally	11KV	Husnabad	03.30	05.30	02.00		Jumper cut	No	
5	Koheda		Venkateshwarapally	11KV	Husnabad	16:40	18:10	1:30		Conductor snapped	No	
1	RR N	Medchal	IDA Kistapur	11KV	Medchal	17:45	18:52	1:07		11KV Pin Insulator failed at NED Company	No	
2		Laxmapur	IDA-I	11KV	Medchal	18.46	21.00	02.14		Tree fallen on the 11KV Line at Laxmapur Village	No	
3		Laxmapur	Laxmapur	11KV	Medchal	18.46	21.30	02.44		11KV Pole damaged at Veeralal Poultry farm	No	
1	RR E	IDA Uppal	Ram Reddy Nagar	11KV	Habsiguda	7:28	8:44	1:16		11KV Jumper cut at Sri Nagar Colony	No	
2		Cherelapally-I	Phase-I	11KV	Sainikpuri	00.15	00.45	00.30		11KV line 3HG fuse and copper patti cut at Sikh India	No	
3		Sainikpuri	Eshwarpuri	11KV	Sainikpuri	09.25	09.55	00.30		Tree branches touched on 11Kv line at Eshwarpuri	No	
1	HYD N	H.A.L	Samrat	11KV	Bowenpally	05.25	07.57	02.32		Cable fault at Pochamma Temple	Arranged B/F on 11KV B.B.R Hospital feeder	
2		R.P Nilayam	Naga Devatha Temple	11KV	Bowenpally	9:10	10:40	01.30		Twisted lines at Military area	No	
3		Srinagar Colony	Kamma Sangam	11KV	Banjarahills	21:35	22:35	01.00		11KV Jumper cut at Sai Ram Apts.	No	
1	HYD S	Falaknuma	Ravindranaiknagar	11KV	Charminar	20.25	21.30	01.05	EL,OL B-ph	3Way RMU lug burnt out at Little Flower School	No	
1	HYD C	Bathakammakunta	Ahobilmult	11KV	Azamabad	00.32	02.40	02.08	EL	Cable fault at Shanthamma Apts.(1No. DTR Kept Off)	No	
2		Zamistanpur	L.N Nagar	11KV	Azamabad	13.05	14.18	01.13	EL	AB Cable fault at L.N.Nagar	No	