

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		3		3		3			
3	MDK	107	933		2		2		2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	5	1	5	1	5	0	0	
	Grand Total	1082	6468	1	7	1	7	1	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 18.05.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kothur	Aryam Steel	33kv	Shadnagar	19.20	21.02	01.42	E/L	Y Phase Jumper Replacement at Comapany	Aryam Steel	-

TSSPDCL - LMRC / Corporate office

Date: 18.05.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Dirsenapally	Miryala	11kv	Suryapet	06.00	08.30	02.30	E/L	Conductor snapped	-
2		Veliminedu	Gundrampally	11kv	Nalgonda	10.55	16.50	05.55	E/L	Tree branches fallen on 11KV line at Pallagutta	-
3		Pamukunta	Jala	11kv	Bhongiri	09.00	10.00	01.00	E/L	Tree Branchess Fallen at Line Near Jala Village	-
1	MDK	Sadasivpet	TSM	11kv	Sangareddy	16.30	17.32	01.02		BD due to Conductor snapped	-
2		Nasthipur	Industrial	11kv	Jogipet	17.10	18.30	01.20		BD due to Monky fallen on line & Insulator failed	-
1	RR S	ESCI	Nanakramguda	11kv	GCB	01.45	03.10	01.25	BD	11KV Cable failed at Divya Sree, before	-
1	RR N	ICICI	Unique-I	11kv	Medchal	12.20	14.30	02.10	BD	11KV Pole damaged by Lorry at Fire Station	-