

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		90		85		85	5		5Nos 11KV Fdrs Still
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>92</b>	<b>0</b>	<b>87</b>	<b>0</b>	<b>87</b>	<b>5</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	3	2	3	2	3			
2	NLG	144	988		5		5		5			
3	MDK	107	933	4	2	2	2	2	2	2		2Nos 33KV Fdrs Still
4	SDPT			1		1		1				
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>7</b>	<b>10</b>	<b>5</b>	<b>10</b>	<b>5</b>	<b>10</b>	<b>2</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>7</b>	<b>102</b>	<b>5</b>	<b>97</b>	<b>5</b>	<b>97</b>	<b>7</b>	<b>0</b>	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Jaklair	33KV	Narayanapet	00.40	09.15	08.35	EL	Tree branches Fallen on the Line & 2Nos Pin Insulator Replaced at Jaklair Canal & 2No's Pin Insulators Replaced at Lingampally	Makthal	NO
2		Gadwal	RWS	33KV	Gadwal	01.56	03.55	01.59	EL	33KV Insulator failed	Gadwal	Loads Tag from 33KV Nandine feeder
1	MDK	Narayankhed	Sirgapur	33KV	Jogipet	15.00	17.45	02.45		B/D Due to tree branches fallen on the line		-
2		Narayankhed	Poosalpad	33KV	Jogipet	19.42	23.50	04.08		B/D Due to tree branches fallen on the line		-
3		Jogipet	Chitkul	33KV	Jogipet	21.45		02.15		B/D		-
4		Jogipet	Dakur	33KV	Jogipet	22.20		01.40		B/D		-
1	SDPT	Siddipet	Narayanraopet	33KV	Siddipet	14.20	17.05	02.45		B/D		

## TSSPDCL - LMRC / Corporate office

Date: 21.05.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Rajapur	Muddireddypally	11KV	Jadcherla	07.00	08.55	01.55		B.D.11Kv Phase To Phase Near Mudireddypally(Vi)	-
2		Tirumalapur	Dondlapally	11KV	Jadcherla	08.18	09.50	01.32		B.D.11Kv Phase To Phase Near Dondlapally (V).	-
3		Mothigapur	Gangadarpally	11KV	Jadcherla	01.30	09.00	07.30		B.D.Dtr Fuse Cut And 11kv Jumper Cut Near Gangadarpally (Vi).	-
1	NLG	Arlagaddagudem	N.R.Gudem	11KV	Nalgonda	21.45	06.50	08.05	EL	11KV line cut at agriculture land	-
2		K.M.Pally	K.M.Pally Town	11KV	Devarakonda	15.20	17.20	02.00	EL	1 No Insulator Failed	-
3		Tekumatla	Yandlapally	11KV	Suryapet	12.20	14.00	01.40	EL	Insulator Failed	-
4		G.Malkapuram	G.Malkapuram	11KV	Huzurnagar	19.15	20.50	01.35	EL	11 KV INSLATER FAILED	-
5		MT.Pally	MT.Pally Agl	11KV	Bhongir	05.00	08.30	03.30	EL	HT/LT at Dayyabandathanda Near MT.Pally Village	-
1	MDK	Gaddapotharam -II	Gaddapotharam AGL	11KV	Patancheru	01.30	03.10	01.40		B/D Due to Conductor Snapped	-
2		Sadasivpet	TSM	11KV	Sangareddy	16.00	18.35	02.35		B/D Due to Insulator Failure	-
1	RR E	Moula-Ali	Gayathri Nagar	11KV	Sainikpuri	08.56	09.45	00.49		Ground petrolling done but no visible fault found	-
2		Narapally	Narapally industrial	11KV	Keesara	21.25	22.55	01.30		Tree fallen on 11KV line at Vijaypuri colony main road	-
1		Kundanbagh	Nava Bharath	11KV	IV	20.03	22.20	02.17	EL	Cable fault at Nava Bharath Chambers	-
2		Lodha	Hanuman Temple	11KV	IV	19.30	23.30	04.00	EL	Tree branches fallen on lines at Various Locations	-
3		Lodha	I.E	11KV	IV	19.56	00.46	04.50	EL	Tree branches fallen on lines at Various Locations	-
4		E.S.I	IAS Quarters	11KV	IV	19.59	21.20	01.21	EL	No Visible Fault	-
5		H.P.S	RBI Quarters	11KV	IV	20.05	21.15	01.10	EL	No Visible Fault	-
6		Muffakamza College	IVRCL	11KV	X	20.08	22.31	02.23	EL	Tree branches fallen on lines at D.K Basti	-
7		N.I.M.S	J.V.R Park	11KV	X	20.20	22.15	01.55	OL	Tree branches fallen on lines at Opp: JVR Park	-
8		Kalyan Nagar	Vishwa Bharathi	11KV	X	19.56	22.45	02.49	EL,OL-Bph	Tree branches fallen on lines at Jawahar Nagar	-
9		Kalyan Nagar	A.G Colony	11KV	X	19.57	21.43	01.46	EL,OL-Bph	Tree branches fallen on lines at A.G Colony	-
10		Kalyan Nagar	Vengalrao Nagar	11KV	X	19.59	21.29	01.30	EL,OL-R&Bph	Tree branches fallen on lines at Drug Control	-
11		Muffakamza College	Times of India	11KV	X	20.01	21.42	01.41	EL	Flexi fallen on lines at Road No.3	-
12		Lalaguda	Lalapet	11KV	V	19.35	21.55	02.20	EL	3No.DTR's fault at Lalaguda	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
13	HYD N	Seethaphalmandi	Namal Gundu	11KV	V	19.35	20.45	01.10	EL	No Visible Fault	-
14		Zamistanpur	S.P College	11KV	V	19.36	21.51	02.15	EL,OL-Bph	Tree branches fallen on lines at Venkateshwara Temple	-
15		Lalaguda	St.Ann's	11KV	V	19.36	20.49	01.13	EL	No Visible Fault	-
16		Lalaguda	Vijayapuri	11KV	V	19.39	00.43	05.04	EL,OL	No Visible Fault	-
17		Lalaguda	A.P Dairy	11KV	V	19.40	21.03	01.23	EL	No Visible Fault	-
18		Seethaphalmandi	Warasiguda	11KV	V	19.40	23.15	03.35	EL	Sticks fallen on lines at TRT Garden	-
19		Osm. University	Mettuguda	11KV	V	19.41	23.00	03.19	EL,OL	Tree branches fallen on lines at Railway Club	-
20		Lalaguda	Chenna Reddy	11KV	V	19.42	00.43	05.01	EL,OL	----	Arranged B/F on 11KV Vijayapuri fdr
21		Zamistanpur	MCH Park	11KV	V	19.42	20.55	01.13	EL,OL-R&Bph	No Visible Fault	-
22		Osm. University	Ravindra Nagar	11KV	V	19.52	21.00	01.08	EL	No Visible Fault	-
23		Addagutta	Addagutta	11KV	V	19.55	00.09	04.14	EL	----	Arranged B/F on 11KV Tagore Home & 11KV Tukaram Gate feeders
24		Chilkaiguda	Pragatools	11KV	V	20.20	22.10	01.50	EL	No Visible Fault	----
25		Clock Tower	Station Road	11KV	V	20.20	22.30	02.10	EL,OL	----	Arranged B/F on 11KV Rly Reservation fdr
26		Zamistanpur	S.P College	11KV	V	22.40	00.36	01.56	EL,OL-Bph	Tree branches fallen on lines at Garunda Apts	-
27		Gunrock	Anjaiah Nagar	11KV	VI	19.28	21.08	01.40	EL	No Visible Fault	-
28		Gunrock	M.D.F	11KV	VI	19.30	21.09	01.39	EL	No Visible Fault	-
29		Chinna Thokatta	Hasmathpet	11KV	VI	19.30	20.51	01.21	EL,OL-R&Bph	No Visible Fault	-
30		I.D.P.L	Sakshi	11KV	VI	19.45	23.40	03.55	EL	Tree branches fallen on lines at Bala Nagar Section Office	-
31		I.D.P.L	SIFCO	11KV	VI	19.45	21.30	01.45	EL	No Visible Fault	-
32		I.D.P.L	Vijaya Electrical	11KV	VI	19.45	23.50	04.05	EL	Tree branches fallen on lines at TIE Bala Nagar	-
33		I.D.P.L	Pump House	11KV	VI	19.45	21.50	02.05	EL	No Visible Fault	-
34		I.D.P.L	Bala Nagar	11KV	VI	19.45	01.40	05.55	EL	HT Jumper cut & Tree branches fallen on lines at Bala Nagar	-
35		I.D.P.L	Obulam	11KV	VI	19.45	01.50	06.05	EL	No Visible Fault	-
36		I.D.P.L	Wonder Plast	11KV	VI	19.45	02.20	06.35	EL	Tree branches fallen on lines at Nala, Bala Nagar	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
37		I.D.P.L	Shivalayam	11KV	VI	19.45	02.47	07.02	EL	UG Cable fault	Arranged partial B/F on 11KV Bala Nagar fdr
38		Prashanth Nagar	Prashanth Nagar	11KV	VI	19.50	21.00	01.10	EL	No Visible Fault	-
39		Prashanth Nagar	Time Tek	11KV	VI	19.50	21.15	01.25	EL	No Visible Fault	-
40		H.A.L	Sri Rama	11KV	VI	19.53	20.56	01.03	EL	No Visible Fault	-
41		Chinna Thokatta	Dubai Gate	11KV	VI	20.05	21.45	01.40	All Indication	No Visible Fault	-
42		Bhudevi Nagar	L.N Colony	11KV	C-VI	19.10	01.00	05.50	EL,OL	Cable End Kit failed	Arranged B/F on 11KV Gollaguda fdr
43		Bhudevi Nagar	Adarsh Nagar	11KV	C-VI	19.20	21.50	02.30	EL	No Visible Fault	-
44		R.P Nilayam	Venkatapuram	11KV	C-VI	19.25	21.00	01.35	EL	No Visible Fault	-
45		Gunrock	AWHO Colony	11KV	C-VI	19.28	23.40	04.12	EL	Tree branches fallen on lines at AWHO Colony	-
46		Bhudevi Nagar	Maruthi Nagar	11KV	C-VI	19.30	23.25	03.55	EL	Tree branches fallen on lines at Maruthi Nagar	-
47		R.P Nilayam	Saraswathi Nagar	11KV	C-VI	19.30	23.55	04.25	EL	Tree branches fallen on lines at Saraswathi Nagar	-
48		R.P Nilayam	Alwal	11KV	C-VI	19.30	00.30	05.00	EL	Tree branches fallen on lines at Alwal	-
49		R.P Nilayam	Ram Nagar	11KV	C-VI	19.30	01.27	05.57	EL	Tree branches fallen on lines at Ram Nagar	-
50		R.P Nilayam	Rythu Bazar	11KV	C-VI	19.30	05.10	09.40	EL	LT Pole bend near Railway Track	Arranged partial B/F on 11KV R.P Nilayam-2 feeder
51		R.P Nilayam	Vaisnavi Matha Temple	11KV	C-VI	19.30	06.00	10.30	EL	Tree branches fallen on lines at Petrol Bunk	-
52		Bhudevi Nagar	Shastry Nagar	11KV	C-VI	19.32	00.45	05.13	EL,OL	Tree branches fallen on lines at Teachers Colony	-
53		Bhudevi Nagar	Gollaguda	11KV	C-VI	19.33	21.52	02.19	EL	No Visible Fault	-
54		Gunrock	Surya Enclave	11KV	C-VI	19.35	22.01	02.26	EL	No Visible Fault	-
55		Gunrock	Gymkhana	11KV	C-VI	19.36	21.01	01.25	EL	No Visible Fault	-
56		Nehru Nagar	Rezimental Bazar	11KV	C-VI	19.36	20.45	01.09	EL,OL	No Visible Fault	-
57		Gunrock	Lal Bazar	11KV	C-VI	19.45	21.11	01.26	EL,OL	No Visible Fault	-
58		Gunrock	Bowenpally	11KV	C-VI	19.50	21.02	01.12	EL,OL	No Visible Fault	-
59		Gymkhana	Apollo	11KV	C-VI	19.51	21.55	02.04	EL,OL-Bph	Tree branches fallen on lines at Apollo & O/G Jumper cut at SS	-
60		Gymkhana	Balaji Enclave	11KV	C-VI	19.51	21.22	01.31	EL,OL-Bph	Tree branches fallen on lines at Balaji Enclave	-
61		Gymkhana	Balamrai	11KV	C-VI	19.51	22.55	03.04	EL	Tree branches fallen on lines at Balamrai	-
62		Gymkhana	Pared Grounds	11KV	C-VI	19.51	23.05	03.14	EL,OL-Bph	Tree branches fallen on lines at Pared Grounds	-
63		Gymkhana	Ranibagh	11KV	C-VI	19.51	21.25	01.34	EL,OL-Bph	Tree branches fallen on lines at Ranibagh	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
64		Gymkhana	Sikh Village	11KV	C-VI	19.51	21.35	01.44	EL,OL-Bph	Tree branches fallen on lines at Sikh Village	-	
65		Gymkhana	Tadbund Temple	11KV	C-VI	19.51	22.11	02.20	EL,OL-Bph	Tree branches fallen on lines at Tadbund Temple	-	
66		Gymkhana	Picket	11KV	C-VI	19.51	21.50	01.59	EL,OL-Bph	No Visible Fault	-	
67		Gunrock	Medchal	11KV	C-VI	19.52	01.10	05.18	EL	No Visible Fault	Arranged partial B/F on 11KV Khanajiguda fdr	
68		Chinna Thokatta	Panchavati Colony	11KV	C-VI	19.55	20.56	01.01	EL,OL-Y&Bph	No Visible Fault	-	
69		Chinna Thokatta	Park View Enclave	11KV	C-VI	20.06	21.25	01.19	EL,OL-Y&Bph	No Visible Fault	-	
70		Gunrock	Tirumalagiri	11KV	C-VI	21.45	05.15	07.30	OL-R&Bph	2No. DTR's fault at Biryani Darbar	-	
71		I.D.P.L	I.E	11KV	VI	19.45			EL		-	
72		I.D.P.L	SVCIE	11KV	VI	19.45			EL		-	
73		H.A.L	Indian Rubber	11KV	VI	19.49			EL		-	
74		R.P Nilayam	Naga Devatha Temple	11KV	C-VI	19.30			EL		-	
75		R.P Nilayam	Venkatapuram	11KV	C-VI	19.30			EL		-	
1		HYD C	Chilkalguda	Musheerabad	11KV	I	19.40	21.06	01.26	EL	No Visible Fault	-
2			Lake View	Satyam Computers	11KV	I	20.05	21.20	01.15	EL	No Visible Fault	-
3			Z.P Office	Anand Nagar	11KV	I	20.06	22.30	02.24	EL	Pin Insulator flash over at Anand Nagar Post Office	-
4	Chilkalguda		Bholakpur	11KV	I	20.20	21.50	01.30	EL	No Visible Fault	-	
5	Indira Park		Ambedkar Nagar	11KV	I	20.20	21.45	01.25	EL	No Visible Fault	-	
6	Indira Park		Goshala	11KV	I	20.30	22.00	01.30	EL	Pin Insulator flash over at Yellamma Temple	-	
7	Chilkalguda		Parsigutta	11KV	II	19.40	22.00	02.20	EL	No Visible Fault	-	
8	Bathkammakunta		Saibaba Temple	11KV	II	19.44	21.01	01.17	EL	Tree branches fallen on lines at Saibaba Temple	-	
9	Zamistanpur		Balaji Nagar	11KV	II	19.47	21.01	01.14	EL	No Visible Fault	-	
10	Industrial Area		Azamabad Key SS	11KV	II	19.50	21.10	01.20	EL	No Visible Fault	-	
11	Narayanaguda		Chikkadapally	11KV	II	20.08	00.05	03.57	EL,OL	No Visible Fault	-	
12	Chilkalguda		Golconda X-Roads	11KV	II	20.23	22.15	01.52	EL	No Visible Fault	-	
13	Osm. University		Boudha Nagar	11KV	II	20.35	23.35	03.00	EL	Pin Insulator flash over at Matha Temple	-	
14	Vittalwadi		APCO	11KV	II	20.40	22.40	02.00	EL,OL-Bph	Tree branches fallen on lines at Opp: Narayanaguda W.W	-	
15	S.D Hospital		Ahmed Nagar Cable	11KV	VII	20.06	22.04	01.58	EL	Insulator flash over at Military Wall	-	