

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	7	1	7	1	7			
7	RR(E)	168	403		4		4		4			
8	Hyd	194	1044		11		11		11			
	Total	606	3055	1	22	1	22	1	22	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	6	4	6	4	6	4			
2	NLG	144	988		5		5		5			
3	MDK	107	933		1		1		1			
4	SDPT			1	6	1	4	1	4		2	2Nos 11KV Fdrs Still
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	7	16	7	14	7	14	0	2	
	Grand Total	1082	6468	8	38	8	36	8	36	0	2	

TSSPDCL - LMRC / Corporate office

Date: 22.05.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Thirumalapur	Dondlapally	11KV	Jadcherla	07.40	11.50	04.10		Phase To Phase Near Dondlapally(V)	-
2		Velgomla	Velgomla	11KV	Jadcherla	05.30	08.15	02.45		11KV Jumper cut near Velgomla(V)	-
3		Udithyal	Udithyal	11KV	Jadcherla	00.00	02.15	02.15		Phase To Phase Near UdityhalV)	-
4		Marrikal	Kanmankalwa	11KV	Jadcherla	02.00	07.30	05.30		11KV Wire cut near kistampally(V)	-
1	NLG	Mukundapuram	Kalluru	11KV	Huzurnagar	16.10	17.20	01.10	E/L	11Kv jumper cut	-
2		Mukundapuram	Mukundapuram	11KV	Huzurnagar	06.45	09.40	02.55	E/L	11Kv line Snapped	-
3		Y.Singaram	Y.Singaram	11KV	Huzurnagar	12.30	13.35	01.05	E/L	11Kv line Snapped	-
4		Kudakuda	Ilapuram	11KV	Suryapet	07.00	09.40	02.40	E/L	Insulator Failed	-
5		Nemaragommula	Jameelapeta	11KV	Bhongir	06.00	09.32	03.32	OL	HT/LT Near Jameelapeta (V)	-
1	MDK	EPIP-I	Biocon	11KV	Sangareddy	11.30	13.35	02.05		BD due to Conductor snapped	-
1	SDPT	Akunoor	Dommata	11KV	Husnabad	18.20	20.25	02.05		poles broken	-
2		Akunoor	Aknor 24 Hrs	11KV	Husnabad	19.30	21.00	01.30		poles broken	-
3		Komuravelly	Komuravelly Agl	11KV	Husnabad	19.05	20.10	01.05		poles broken	-
4		Komuravelly	Inapur + Posanpally + Inapur 24 Hrs	11KV	Husnabad	14.00	15.39	01.39		poles broken	-
5		Chityal	Chityal Agl	11KV	Husnabad	19.20		Still		poles broken	-
6		Chityal	Dommata	11KV	Husnabad	19.20		Still		poles broken	-
1	RR N	Petbasheerabad	Balaji Hospital	11KV	Medchal	20.45	23.10	02.25		Tree fallen on the 11KV Line at Surya Convention	-
2		Medchal	Navadurga	11KV	Medchal	03.21	08.20	04.59		Tree fallen on the 11KV Line at Vidyut Control Board	-
3		Devarayamjal	Kottapet	11KV	Medchal	04.20	07.25	03.05		Tree Fallen on the 11KV Line at Kottapet	-
4		Kistapur	IDA Hanuman	11KV	Medchal	02.40	04.50	02.10		Tree fallen on the 11KV Line at Ravakole X Roads	-
5		Thurkapally	Yadaram	11KV	Medchal	20.10	22.20	02.10		11KV Pin Insulator failed at Mamidi Thota(Jumper opened)	-
6		GP Pally	GP Pally	11KV	Medchal	09.30	10.45	01.15		11KV Line Replaced at Ayodhya Chowrasta	-
7		Shameerpet	Thumkunta	11KV	Medchal	21.20	22.05	00.45		11KV Pin Insulator failed at Thumkunta Village	-
1	RR E	RGK	Kowkooor	11KV	Sainikpuri	04.30	07.30	03.00		Tree fallen on 11Kv line at Surabhi Enclave (AE/OP/Yapral)	-
2		RGK	Barshipet	11KV	Sainikpuri	04.30	15.00	10.30		Tree branches fallen and 11Kv pole broken at Bondalgdada T/F (AE)	-
3		RGK	Nissa	11KV	Sainikpuri	04.30	16.20	11.50		Tree branches fallen and 2 11KV pole damaged at Hakimpet and Singipalli (AE)	-
4		CRPF	Chennapur	11KV	Keesara	07.30	09.00	01.30		11KV Pin Insulator failed at Abraspally	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Gunrock	Medchal	11KV	Bowenpally	02.01	03.06	01.05	EL,OL	Tree branches fallen on lines at Lalbazar	Arranged B/F on 11KV Lalbazar fdr
2		Bowenpally	Pension Line	11KV	Bowenpally	07.10	09.55	02.45	EL	HT Line snapped at Pension Line & DC fuse failed at SS	-
3		Hakimpet	Risala Bazar	11KV	Bowenpally	09.50	21.45	11.55	EL,OL	Tree branches fallen on lines, 2no.Jumper cut & Inusulator flash over at Bollarum Railway Station (3Nos DTR Off)	Partial feeder chaged at 17:15 Hrs
4		I.D.P.L.	Wonder Plast	11KV	Bowenpally	11.15	12.55	01.40	OL-Bph	Pole damaged at Nala	-
5		Osm. University	Ladies Hostel	11KV	Sec-Bad	19.56	21.50	01.54	All Indication	Tree branches fallen on lines at Ladies Hostel	Partial feeder charged at 20:32 Hrs
6		Seethaphalmandi	Medibavi	11KV	Sec-Bad	20.05	21.10	01.05	EL,OL-Rph	Tree branches fallen on lines at Medibavi	-
7		Seethaphalmandi	Namalagundu	11KV	Sec-Bad	20.05	21.30	01.25	EL,OL-Rph	Tree branches fallen on lines at Sai Latha Functional Hall	-
8		Macha Bollarum	Radhasath Sang	11KV	Bowenpally	20.45	21.57	01.12	EL	No Visible Fault	-
9		Seethaphalmandi	Medibavi	11KV	Sec-Bad	22.05	23.10	01.05	EL,OL-Rph	Dis flash over & Cloth fallen on lines at Medibavi Garden	-
1	HYD S	Salarjung	Pather Gatti	11KV	Charminar	20.20	21.45	01.25	EL,OL-Rph	Cable End Kit fault at Osmania Bazar	-
1	HYD C	Bathakammakunta	Saibaba Temple	11KV	Azamabad	20.52	22.18	01.26	EL,OL-Rph	Tree branches fallen on lines near Sri Chaintanya College	-