

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	4	1	4	1	4			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044	1	1	1	1	1	1			
	Total	606	3055	2	6	2	6	2	6	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	3	3	3	3	3			
2	NLG	144	988		6		6		6			
3	MDK	107	933	8	5	8	5	8	5			
4	SDPT				13		13		13			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	11	27	11	27	11	27	0	0	
	Grand Total	1082	6468	13	33	13	33	13	33	0	0	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Krishna	33kv	Narayanapet	12.30	16.40	04.10	E/L	Pin insulator damaged and replacement	Krishna	-
2		Kodangal	Hamsanpally	33kv	Vikarabad	02.30	08.55	06.25	E/L	Insulator Replacement	Hamsanpally	-
3		Kodangal	Kothur	33kv	Vikarabad	02.05	07.30	05.25	E/L	Insulator Replacement	Kothur	-
1	MDK	Zaheerabad	Jharasangam	33kv	Zaheerabad	02.00	09.15	07.15		BD due to Conductor snapped	Jharasangam	Alternate Supply Arranged from 132KV Zaheerabad, 33KV Machnoor feeder at 9:00 am-
2		Narayankhed	Poosalpad	33kv	Jogipet	01.55	06.50	04.55		B/D due to Conductor snapped	Poosalpad	-
3		Narayankhed	Sirgapur	33kv	Jogipet	01.55	08.10	06.15		B/D Pin Insulator failure	Sirgapur	-
4		Kandi	IIT Hyderabad	33kv	Sangareddy	02.00	08.00	06.00		B/D due to 8 Nos. Pin Insulators failure	IIT Hyderabad	-
5		Kandi	BDL	33kv	Sangareddy	01.30	02.30	01.00		B/D due to Pin Insulator failure	BDL	-
6		Kandi	Aradana	33kv	Sangareddy	01.00	08.00	07.00		B/D due to Pin Insulator failure	Aradana	-
7		Kandi	Alkabeer	33kv	Sangareddy	01.50	06.50	05.00		B/D due to Pin Insulator failure	Alkabeer	-
8		Gummadidala	GPSS-I	33kv	Patancheru	02.00	06.50	04.50		B/D due to Conductor snapped	GPSS-I	-
1	RR N	132KV Medchal	33KV Petbasheerabad	33kv	Medchal	14.00	15.50	01.50		33KV Pin Insulator failed at Kandlakoya	33KV Petbasheerabad	-
1	HYD N	132KV Jubilee Hills	Sundew service) (HT	33kv	Jubilee Hills	09.15	17.40	08.25	EL,OL-R,Y&Bph	Cable damaged by unknown person at Revanth Reddy's House	Sundew service) (HT	-

TSSPDCL - LMRC / Corporate office

Date: 24.05.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	Moosapet	11KV	Jadcherla	07.00	09.15	02.15		11KV Insulator fail near Janampet	-
2		Annasagar	Tatikonda	11KV	Jadcherla	06.30	09.45	03.15		11KV Insulator fail near Tatikonda	-
3		Boothpur	Boothpur@	11KV	Jadcherla	14.30	15.10	00.40		100KVA DTR Fail near Boothpur	-
1	NLG	G.Yadavally	Kurampally	11KV	Nalgonda	10.00	12.50	02.50	E/L	11KV Line Cutting	-
2		Nakkalapally	Pallepadu	11KV	Nalgonda	11.35	14.00	02.25	E/L	11KV Line Jumper Cutting	-
3		Athmakur(S)	Gottemukkalagude	11KV	Suryapet	07.00	09.20	02.20	E/L	Conductor snapped	-
4		Mattapally	Suithanpuram	11KV	Huzurnagar	14.45	17.20	02.35	E/L	Due to 11Kv line Snapped	-
5		Y.Singaram	Y.Singaram	11KV	Huzurnagar	18.45	20.15	01.30	E/L	Due to 11Kv Jumper cutted	-
6		BP.Pally	Mukthapur	11KV	Choutuppal	12.50	14.00	01.10	E/L	11 kv Insulator Failed at Kondamoni cheruvu Near Mukthapur Village	-
1	MDK	Sadashivapet	Nandikandi	11KV	Sangareddy	03.00	06.10	03.10		B/D due to Jumper cut	-
2		Patancheru	Santhi Nagar	11KV	Patancheru	01.05	03.05	02.00		B/D due to Conductor snapped	-
3		Cheryal	Julkal	11KV	Sangareddy	01.05	03.00	01.55		B/D due to Insulator failure	-
4		Cheryal	Indrakaran	11KV	Sangareddy	03.00	06.00	03.00		B/D due to Jumper cut	-
5		Sangareddy Town-I	Tallapally	11KV	Sangareddy	01.35	02.15	00.40		B/D Due to tree branches fallen on the line	-
1	SDPT	MUSTHYAL	VEERANNAPET	11KV	Husnabad	17.30	18.40	01.10		BD LINE SNAPPED RECTIFIED	-
2		GURUVANNAPET	THAPASPALLY	11KV	Husnabad	00.00	12.40	12.40		BD DTR FAILURE RECTIFIED	-
3		KOMURAVELLY	INAPURL AGL	11KV	Husnabad	02.45	10.50	08.05		BD POLE DAMGED RECTIFIED	-
4		REBARTHY	GAGILLAPUR	11KV	Husnabad	08.20	18.00	09.40		BD 11KV INSULATOR FAIL RECTIFIED	-
5		PANDHILLA	POTLAPALLY	11KV	Husnabad	06.30	09.00	02.30		BD DTR PROBLEM RECTIFIED	-
6		PANDHILLA	PANDHILLA R	11KV	Husnabad	06.30	08.00	01.30		BD DTR PROBLEM RECTIFIED	-
7		AKKANAPET	GOLLAKUNTA	11KV	Husnabad	00.40	09.20	08.40		BD LINE SNAPPED RECTIFIED	-
8		GANDIPALLY	RAMARAVARAM	11KV	Husnabad	13.40	14.25	00.45		BD LINE SNAPPED	-
9		REGULAPALLY	SHEELAPUR	11KV	Husnabad	09.10	10.00	00.50		BD LINE SNAPPED	-
10		THOTAPALLY	THOTAPALLY	11KV	Husnabad	00.00	08.40	08.40		BD INSULATOR FAIL	-
11		BEJJANKI	KALLEPALLY	11KV	Husnabad	00.00	15.00	15.00		BD INSULATOR FAIL	-
12		RAMCHANDRAPUR	RAMCHANDRAPUR R	11KV	Husnabad	00.00	12.20	12.20		BD JUMPPER SNAPED	-
13		KOHEDA	KANAL	11KV	Husnabad	00.00	11.30	11.30		BD LINE SNAPPED RECTIFIED	-
1	RR N	Mayurinagar	Prashathnagar	11KV	Kukatpally	05.25	06.40	01.15		11kv Pin insulator Failure Near Surakha Apt Mayurinagar	-
2		Dulapally	Dulapally Village	11KV	Medchal	02.25	04.40	02.15		315KVA T/F HG fuse Insulator failed at Dulapally Village	-
3		Gagillapur	Sundhara Ashrammam	11KV	Kukatpally	03.00	04.00	01.00		Phase-To phase line Cut At asharamamma	-
4		Athiwelly	Somaram	11KV	Medchal	03.30	05.20	01.50		Tree fallen on the 11KV Line at Somaram Village	-
1	RR E	St.No.08	Green Hills	11KV	Habsiguda	18.36	19.33	00.57		11KV Overhead AB cable failed near Saketh Apartment St.No.08 & 11KV Jumper opened at Saketh Aartment	-
1	HYD N	Marredpally	Jyothi Colony	11KV	Clock Tower	14.30	15.35	01.05	EL,OL-Yph	No Visible Fault	-