

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044	1	3	1	3	1	3			
	Total	606	3055	1	7	1	7	1	7	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	1	3	1	3	1			
2	NLG	144	988		9		9		9			
3	MDK	107	933									
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	14	3	14	3	14	0	0	
	Grand Total	1082	6468	4	21	4	21	4	21	0	0	

TSSPDCL - LMRC / Corporate office

Date: 28.05.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Damargidda	33KV	Mahabubnagar	02.25	03.30	01.05	E/L	No Visible Fault	Maddur	No
2		Thirumalaipally	Veltoor	33KV	Wanaparthi	06.55	07.43	00.48	E/L	No Visible Fault	Thirumalaipally	No
3		Gadwal	Gadwal New	33KV	Gadwal	07.15	09.05	01.50	E/L	for Insulator Replaced at Pudoor Road	Gadwal	No
1	HYD C	132KV Asif Nagar	Golconda (PTR-1&2)	33KV	Asif Nagar	17.03	17.05	00.02	OL-Bph	Under breakdown	132KV Asif Nagar	Loads transferred onto 132KV J' Hills SS via 33KV Golconda SS

TSSPDCL - LMRC / Corporate office

Date: 28.05.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Marikal	Kalmankalwa	11KV	Jadcherla	09.40	11.40	02.00		BD due to 11 KV pin insulater fail near kothapally.	-
1	NLG	Edloor	Parada	11KV	Nalgonda	07.30	10.00	02.30	E/L	11 KV Jumper Cut Under SS-3 at Parada	-
2		Pamanagundla	Pittampally	11KV	Nalgonda	04.00	08.00	04.00	E/L	Tree Fallen on 11 KV Line	-
3		Matoor	Matoor	11KV	Miryalaguda	13.15	14.30	01.15	E/L	Tree Fallen on 11 KV Line	-
4		Akupamula	K.K.gudem	11KV	Huzurnagar	05.20	07.00	01.40	EL	Due to 11kv Jumper cutted	-
5		Sirikonda	Sirikonda	11KV	Huzurnagar	11.50	15.00	03.10	EL	Due to 11kv linecutted	-
6		Chanupally	Chanupally	11KV	Huzurnagar	09.45	12.50	03.05	EL	Due to 11kv line snapped	-
7		Patelgudem	Srinivasapuram	11KV	Bhongiri	04.40	08.40	04.00	OL	HT/LT Near Srinivasapuram Village	-
8		Bondugula	Bondugula Agl	11KV	Bhongiri	13.40	17.10	03.30	EL	11 kv Pin Insulator Binding Cut Near Bondugula Village	-
9		Mothkur	Kondagadapa	11KV	Bhongiri	04.30	09.15	03.45	OL	AB Switch Copper Patti Cut Near Kondagadapa Village	-
1	SDPT	Thotapally	Mallampally	11KV	Husnabad	03.00	05.30	02.30		Line cutting	-
2		Akkannapet	Pakilnayak Thanda	11KV	Husnabad	13.30	16.30	03.00		Test charge	-
3		Dharmaram	Dharmaram(R.)	11KV	Husnabad	00.00	10.00	10.00		Insulator problem	-
4		Marmamula	Marmamula	11KV	Husnabad	08.50	09.00	00.10		DTR connection	-
1	RR S	Lanco Hills	Khajaguda	11KV	Gachibowli	03.00	04.33	01.33	BD	11kv Conductor snapped near Delhi Public School	-
2		Nanakramguda	Manjeera	11KV	Gachibowli	01.50	03.20	01.30	BD	11kv Line petroling, No visible fault found(LABS Opened at Erramatti Thanda)	-
1	RR N	Keshavaram	Potharam	11KV	Medchal	18.00	18.50	00.50		11KV Pin Insulator failed & Replaced at Potharam Village	-
1	RR E	NGRI	HBG	11KV	Habsiguda	15.05	16.06	01.01		Tree branchese fallen on 11kv line at Madhu Enclave st no 4	-
1	HYD N	Road No.12	Kanaka Durga	11KV	Banjarahills	00.30	01.30	01.00	EL,OL-Bph	Cable fault	Arranged B/F on 11KV Kalinga fdr
2		LV Prasad Marg	LV Prasad Film Lab	11KV	Banjarahills	16.58	20.06	03.08	EL,OL-Bph	Cable fault at Pradeep Constructions	-
1	HYD S	Miralam	N.S.Kunta	11KV	Charminar	10.10	11.15	01.05	EL,OL	Tree branches fallen on lines at Gudi Ka Dhawakhana	-