

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044	1	3	1	3	1	3			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>1</b>	<b>10</b>	<b>1</b>	<b>10</b>	<b>1</b>	<b>10</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988	1	7	1	7	1	7			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>10</b>	<b>2</b>	<b>10</b>	<b>2</b>	<b>10</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>3</b>	<b>20</b>	<b>3</b>	<b>20</b>	<b>3</b>	<b>20</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 29.05.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Achampet	Nadimpally	33KV	Nagarkurnool	06.00	08.10	02.10	EL	Tree follen on the 33KV line and Conductor snapped		no
1	NLG	Aitipamula	Aitipamula	33KV	Nalgonda	08.01	13.20	05.19	E/L	33 KV line jumper cut		-
1	HYD C	132KV Asif Nagar	ITI Mallepally	33KV	Asif Nagar	04.30	04.45	00.15	EL,OL-Bph	Under Breakdown	132KV Asif Nagar	Loads transferred onto 132KV NIMS SS via 33KV Nampally SS

## TSSPDCL - LMRC / Corporate office

Date: 29.05.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kollur	Nawabpet	11KV	Jadcherla	13.25	14.50	01.25		B.D.11Phase To Phas Near Jangamaiahpally( Vi).	-
1	NLG	Koppole(K)	Beemavaram	11KV	Nalgonda	08.40	12.10	03.30	E/L	HT/LT line milting	-
2		Aitipamula	CH.Annaram	11KV	Nalgonda	12.00	13.40	01.40	E/L	11 KV line cut	-
3		Nuthankal	Yedavelly	11KV	Suryapet	08.50	10.45	01.55	E/L	Insulator flashover	-
4		Y.Singaram	Magdum nagar	11KV	Huzurnagar	12.55	14.10	01.15	E/L	Due to 11Kv line snapped	-
5		Dondapadu	Kakatiya	11KV	Huzurnagar	10.15	13.30	03.15	E/L	Due to 11Kv line snapped	-
6		Chanupally	Chanupally	11KV	Huzurnagar	06.00	09.00	03.00	E/L	Due to HT/LT fault occurred	-
7		Kondamadugu	Kondamadugu	11KV	Bhongir	04.00	09.55	05.55	E/L	11 kv Line Snapped & HT/LT Near Jainapally Village	-
1	SDPT	Nagapuri	Nagapuri	11KV	Husnabad	15.40	17.50	02.10		LT line cut	
2		Komuravelli	Kadaverugu	11KV	Husnabad	15.45	16.55	01.10		Heavy gale and wind	
1	RR N	Bowrampet	Bowrampet Village	11KV	Jeedimetla	07.31	08.45	01.14	OL	Tree Branchesh fallon the 11kv line Nera Bowrampet Comman	-
2		Kompally	Aparna	11KV	Medchal	07.53	08.34	00.41	BD	Tree Fallen on the 11KV Line at HP Petrol bunk,Kompally	-
3		Kistapur	IDA Hanuman	11KV	Medchal	14.30	15.30	01.00	BD	11KV AB Cable failed at Virat Company ( Jumper opened )	-
4		Laxmapur	IDA Laxmapur	11KV	Medchal	15.14	16.20	01.06	BD	Tree fallen on the 11KV Line at Guru Raja Company	-
1	RR E	Ghatkesar	Ghatkesar	11KV	Keesara	16.00	17.20	01.20		Tree branches fallen on 11kv line at Ghatkesar primary School Backside	-
2		Ghatkesar	Balaji Nagar	11KV	Keesara	16.00	17.40	01.40		Tree branches fallen on 11kv line at Kondapur	-
3		Ghatkesar	Kondapur	11KV	Keesara	16.00	17.30	01.30		11KV line cut at Barla Doddi	-
1	HYD N	Bowenpally	Ferozeguda	11KV	Bowenpally	15.30	17.45	02.15	EL,OL-Bph	Cable fault at Railway Track	Arranged partial loads B/F on 11KV Bala Nagar feeder
2		H.A.L	I.A.L	11KV	Bowenpally	15.45	18.15	02.30	EL	Cable fault	Arranged B/F on 11KV IAF feeder
1	HYD S	Exhibition	Seetharampet	11KV	Begumbazar	10.45	12.44	01.59	All Indication	Tripping Coil fault at SS	-